

BL1600
C-Programmable Controller
User's Manual
Revision E

BL1600 User's Manual

Part Number 019-0016 • Revision E

Last revised on February 9, 2000 • Printed in U.S.A.

Copyright

© 1999 Z-World, Inc. • All rights reserved.

Z-World reserves the right to make changes and improvements to its products without providing notice.

Trademarks

- Dynamic C[®] is a registered trademark of Z-World, Inc.
 - Windows[®] is a registered trademark of Microsoft Corporation
 - PLCBus[™] is a trademark of Z-World, Inc.
 - Hayes Smart Modem[®] is a registered trademark of Hayes Microcomputer Products, Inc.
-

Notice to Users

When a system failure may cause serious consequences, protecting life and property against such consequences with a backup system or safety device is essential. The buyer agrees that protection against consequences resulting from system failure is the buyer's responsibility.

This device is not approved for life-support or medical systems.

All Z-World products are 100 percent functionally tested. Additional testing may include visual quality control inspections or mechanical defects analyzer inspections. Specifications are based on characterization of tested sample units rather than testing over temperature and voltage of each unit. Z-World may qualify components to operate within a range of parameters that is different from the manufacturer's recommended range. This strategy is believed to be more economical and effective. Additional testing or burn-in of an individual unit is available by special arrangement.

Company Address

Z-World, Inc.

2900 Spafford Street
Davis, California 95616-6800
USA



Telephone: (530) 757-3737
Facsimile: (530) 753-5141
Web Site: <http://www.zworld.com>
E-Mail: zworld@zworld.com

TABLE OF CONTENTS

About This Manual	vii
Chapter 1: Overview	11
Introduction	12
Features	13
Options and Upgrades	14
Development and Evaluation Tools	15
Software	15
CE Compliance	16
Chapter 2: Getting Started	17
Initial BL1600 Setup	18
Parts Required	18
Connecting the BL1600 to a Host PC	18
Running Dynamic C	21
Chapter 3: BL1600 Operation	23
Operating Modes	24
Run Mode	25
EPROM	25
Programming EPROMs	25
Memory Size	25
Copyrights	27
Chapter 4: System Development	29
BL1600 Interfaces	30
Digital Inputs	30
Digital Outputs	30
Serial Ports	32
Miscellaneous Signals	33
PLCBus Port	34
Dynamic C Libraries	35

Driver Software	36
Digital Inputs	36
Digital Outputs	36
High-Speed DMA Counter	37
Battery-Backed Clock	38
Writing to Flash EPROM	38
Virtual Drivers	39
Invoking the Virtual Driver	41
Virtual Driver Variables	41
Digital Inputs	41
Digital Outputs	41
Timers	42
Serial Communication	43
RS-232 Communication	43
Receive and Transmit Buffers	43
Echo Option	43
CTS/RTS Control	43
XMODEM File Transfer	44
Modem Communication	44
Software Support	45
Interrupt Handling for Z180 Port 0	45
RS-232 Software Support	46
XMODEM Commands	48
Miscellaneous Functions	49
Master-Slave Networking	51
RS-485 Network Hardware Connections	52
RS-485 Network Software Support	54
Miscellaneous RS-485 Network Functions	55
Support Libraries and Sample Programs	56
Direct Programming of the Serial Ports	57
Attainable Baud Rates	57
Z180 Serial Ports	58
Asynchronous Serial Communication Interface (ASCI)	60
ASCI Status Registers	60
CTS1E (CTS Enable, Channel 1)	61
RDRF (Receiver Data Register Full)	61
ASCI Control Register A	62
ASCI Control Register B	63

Appendix A: Troubleshooting	67
Out of the Box	68
Dynamic C Will Not Start	69
BL1600 Resets Repeatedly	69
Dynamic C Loses Serial Link	69
Common Programming Errors	70
Appendix B: Specifications	71
Electrical and Mechanical Specifications	72
BL1600 Mechanical Dimensions	73
Factory Default Jumper Positions	74
Installation Concepts	77
Connectors	77
Power Consumption and Heat Dissipation	77
High-Voltage Drivers	78
Sinking Driver	78
Sourcing Driver	79
Appendix C: Prototyping Board	81
Introduction	82
Features	82
System Description	83
Connecting the Prototyping Board to the BL1600	84
Power Supply	84
Power Rails	85
Interface with BL1600	87
Prototyping Board Pinouts	88
Appendix D: Sinking and Sourcing Drivers	89
BL1600 Series Sinking and Sourcing Outputs	90
Installing Sourcing Driver	92
Using Output Drivers	93
Appendix E: PLCBus	95
PLCBus Overview	96
Allocation of Devices on the Bus	100
Bit Devices	100
8-Bit Devices	101
Expansion Bus Software	101

Appendix F: EEPROM	107
EEPROM Parameters	108
Baud Rate	108
Startup Mode	108
Clock Speed	109
Changing Parameters Stored in EEPROM	109
Library Routines	109
Appendix G: Memory, I/O Map, and Interrupt Vectors	111
BL1600 Memory	112
Memory and Input/Output Cycle Timing	113
Input/Output Cycle Timing	114
Execution Timing	115
Memory Map	116
Input/Output Select Map	116
Z180 Internal Input/Output Registers Addresses 0x00–0x3F	116
Epson 72421 Timer Registers 0x4000–0x400F	118
Other Addresses	119
Interrupt Vectors	121
Nonmaskable Interrupts	122
Power Failure Interrupts	122
Jump Vectors	123
Interrupt Priorities	124
Appendix H: Power Management	125
ADM691 Power Supervisor	126
Power Failure Management	127
Power Failure Sequence	127
Holdup Time	129
Multiple Power-Line Insults	129
Sample Program to Handle Power Failure	130
Appendix I: Battery	131
Battery Life and Storage Conditions	132
Replacing Soldered Lithium Battery	132
Battery Cautions	133
Index	135

Schematics

ABOUT THIS MANUAL

This manual provides instructions for installing, testing, configuring, and interconnecting the Z-World BL1600 controller. Instructions are also provided for using Dynamic C[®] functions.

Assumptions

Assumptions are made regarding the user's knowledge and experience in the following areas.

- Ability to design and engineer the target system that the BL1600 will control.
- Understanding of the basics of operating a software program and editing files under Windows on a PC.
- Knowledge of the basics of C programming.



For a full treatment of C, refer to the following texts.

The C Programming Language by Kernighan and Ritchie
and/or

C: A Reference Manual by Harbison and Steel

- Knowledge of basic assembly language and architecture for the Z180 microprocessor.



For documentation from Zilog, refer to the following texts.

Z180 MPU User's Manual

Z180 Serial Communication Controllers

Z80 Microprocessor Family User's Manual

Terms and Abbreviations

Table 1 lists and defines the acronyms that may be used in this manual.

Table 1. Acronyms

Acronym	Meaning
EPROM	Erasable Programmable Read-Only Memory
EEPROM	Electrically Erasable Programmable Read-Only Memory
NMI	Nonmaskable Interrupt
PIO	Parallel Input/Output Circuit (Individually Programmable Input/Output)
PRT	Programmable Reload Timer
RAM	Random Access Memory
RTC	Real-Time Clock
SIB	Serial Interface Board
SRAM	Static Random Access Memory
UART	Universal Asynchronous Receiver Transmitter

Conventions


Table 2 lists and defines the typographical conventions that may be used in this manual.

Table 2. Typographical Conventions

Example	Description
while	Courier font (bold) indicates a program, a fragment of a program, or a Dynamic C keyword or phrase.
// IN-01...	Program comments are written in Courier font, plain face.
<i>Italics</i>	Indicates that something should be typed instead of the italicized words (e.g., in place of <i>filename</i> , type a file's name).
Edit	Sans serif font (bold) signifies a menu or menu selection.
...	An ellipsis indicates that (1) irrelevant program text is omitted for brevity or that (2) preceding program text may be repeated indefinitely.
[]	Brackets in a C function's definition or program segment indicate that the enclosed directive is optional.
< >	Angle brackets occasionally enclose classes of terms.
a b c	A vertical bar indicates that a choice should be made from among the items listed.

Pin Number 1

A black square indicates pin 1 of all headers.









Measurements

All diagram and graphic measurements are in inches followed by millimeters enclosed in parenthesis.

Icons

Table 3 displays and defines icons that may be used in this manual.

Table 3. Icons

Icon	Meaning
	Refer to or see
	Please contact
	Caution
	Note
	High Voltage
TIP	Tip
	Factory Default

Blank



CHAPTER 1: **OVERVIEW**

Chapter 1 provides an overview and a brief description of the BL1600 features.

Introduction

The BL1600's combination of logic-level inputs/outputs and high-current drivers makes it a versatile controller in a compact "form factor." The BL1600 is ideal for OEM applications such as industrial control and data acquisition.

The BL1600's battery-backed RAM, real-time clock, and EEPROM provide data integrity in the event of power fluctuations or power failure. The BL1600 is readily connected to peripheral devices through standard headers or screw terminals. An optional Prototyping Board facilitates the development of custom circuits and operator interfaces.

Figure 1-1 illustrates the BL1600 board layout.





Figure 1-1. BL1600 Board Layout

Features


The BL1600 includes the following features.

- 12 digital inputs.
- 14 digital outputs.
- RS-485 and RS-232 serial communication.
- 9.216 MHz clock.
- PLCBus port for system expansion.

The BL1600 also includes battery-backed RAM (up to 512K) and a battery-backed real-time clock (an Epson 72421 with time and date functions), EPROM (up to 512K) or flash EPROM (to 256K), programmable timers, DMA, EEPROM (512 bytes standard), a watchdog timer, and power-failure interrupt.


 Appendix B provides detailed specifications for the BL1600.

The maximum power dissipation is 5 W at 50°C with the standard (large) heat sink, and 3 W with the optional small heat sink supplied with the Experimenter's Kit. The maximum operating temperature is 70°C, but the BL1600 may not be able to operate for extended periods at 70°C.

 Chapter 2, "Getting Started," provides further information on environmental constraints.

The BL1600's RS-485 capability allows you to build a network of controllers with links up to several kilometers.

The PLCBus port allows you to expand your system by adding expansion boards, such as Z-World's XP8700 or XP8900, or devices of your own design. The BL1600 is designed to allow you to build and add your own expansion boards. Z-World supplies a Prototyping Board for this purpose.

 Appendix C, "Prototyping Board," provides further information on the Prototyping Board.

Options and Upgrades

The BL1600 Series of controllers has two versions. Table 1-1 lists their standard features.

Table 1-1. BL1600 Series Features

Model	Features
BL1600	9.216 MHz clock, 12 digital inputs, 14 high-current sinking outputs, RS-232/RS-485 serial ports, EEPROM, real-time clock, PLCBus expansion port.
BL1610	BL1600 without serial ports, high-current drivers, EEPROM, or real-time clock.

The following optional items are available for BL1600 Series controllers.

- 128K or 256K flash EPROM to replace regular EPROM.
- 128K or 512K SRAM.
- Prototyping Board.
- XP8700 expansion board to program the BL1600 if the BL1600's RS-232 serial port is required by the application. A full line of Z-World expansion boards is available.



For ordering information, call your Z-World Sales Representative at (530) 757-3737.

Development and Evaluation Tools

The BL1600 is supported by a Developer's Kit that include everything you need to start development with the BL1600.

The Developer's Kit includes these items.

- Programming cables and adapter.
- 24 V DC wall-mount power supply.
- 128K flash EPROM.
- Smaller heat sink.
- Sinking and sourcing high-current driver chips.
- 14-pin and 20-pin breakout cables.

Software

The BL1600 is programmed using Z-World's Dynamic C, an integrated development environment that includes an editor, a C compiler, and a debugger. Library functions provide an easy and robust interface to the BL1600.



Z-World's Dynamic C reference manuals provide complete software descriptions and programming instructions.

CE Compliance

The BL1600 has been tested by an approved competent body, and was found to be in conformity with applicable EN and equivalent standards. Note the following requirements for incorporating the BL1600 in your application to comply with CE requirements.



- The power supply provided with the Development Kit is for development purposes only. It is the customer's responsibility to provide a clean DC supply to the controller for all applications in end-products.
- The BL1600 has been tested to Light Industrial Immunity standards. Additional shielding or filtering may be required for an industrial environment.
- The BL1600 has been tested to EN55022 Class A emission standards. Additional shielding or filtering may be required to meet Class B emission standards.



Visit the “Technical Reference” pages of the Z-World Web site at <http://www.zworld.com> for more information on shielding and filtering.



CHAPTER 2: **GETTING STARTED**

Chapter 2 provides instructions for connecting the BL1600 to a host PC and running a sample program.

Initial BL1600 Setup

Parts Required

- 24 V unregulated DC power supply
- Programming cable
- Optional XP8700 expansion board (needed if the RS-232 port on the BL1600 is required by the application).

The necessary parts are supplied with the Developer's Kit.

Connecting the BL1600 to a Host PC

1. Connect the power supply to the BL1600. Connect the two leads from the DC power supply or wall transformer to header J2 as shown in Figure 2-1. Do not power up the power supply until the remaining steps have been completed.




Figure 2-1. BL1600 Power Supply Connections at Header J2



Be careful to connect the power supply wires to the correct sockets on header H2. The BL1600 may be destroyed in an instant if the power supply is connected to the **wrong** socket. A protective diode prevents damage to the BL1600 if the power supply polarity is reversed.

2. Check jumper settings on header J1. Jumpers on header J1 define the hardware configuration, the mode, and the baud rate. Figure 2-2 shows the jumper settings for the various programming options.





Figure 2-2. BL1600 Programming Jumper Settings for Header J1

 Appendix B, “Specifications,” lists all the jumper settings.

3. Establish a serial communication link. A PC communicates with the BL1600 via Serial Port 0 on the BL1600’s microprocessor using RS-232 protocols. There are two options to install the communication link.

Option 1—BL1600 serial port (header H3).

Use the programming cable to connect the PC’s 9-pin or 25-pin RS-232 serial port to header H3 on the BL1600 as shown in Figure 2-3. Either PC serial port (COM1 or COM2) may be used.




Figure 2-3. Connecting Programming Cable to BL1600 Header H3

Option 2—XP8700 expansion board.

Use the programming cable to connect the PC's 9-pin or 25-pin RS-232 serial port to header H1 on the XP8700. Either PC serial port (COM1 or COM2) may be used. (If you are using a non-Z-World programming cable with an RJ-12 plug instead of a 10-pin connector, connect the RJ-12 plug to the RJ-12 jack on the XP8700.) Connect the XP8700 to the BL1600's PLCBus port as shown in Figure 2-4.




Figure 2-4. Use of XP8700 to Program BL1600

4. The BL1600 is now ready for programming. The power supply may be plugged in and turned on.

Running Dynamic C

Double-click the Dynamic C icon to start the software. Note that the PC attempts to communicate with the BL1600 each time Dynamic C is started. No error messages are displayed once communication is established.

The communication rate, port, and protocol are all selected by choosing **Serial Options** from Dynamic C's **OPTIONS** menu.

The BL1600's default communication rate is 19,200 bps. However, the Dynamic C software shipped by Z-World may be initialized for a different rate. To begin, adjust the communications rate to 19,200 bps.

Make sure that the PC serial port used to connect the serial cable (COM1 or COM2) is the one selected in the Dynamic C **OPTIONS** menu. Select the 1-stop-bit protocol.



See Appendix A, "Troubleshooting," if an error message such as **Target Not Responding** or **Communication Error** appears.



Once the necessary changes have been made to establish communication between the host PC and the BL1600, use the Dynamic C shortcut **<Ctrl Y>** to reset the controller and initiate communication.

Blank



CHAPTER 3: ***BL1600 OPERATION***

Chapter 3 describes how to use the BL1600, with a focus on

- how to set the run and programming modes, and
- how to burn a custom program on EPROM.

Operating Modes

A hardware reset takes place when the BL1600 is powered up, when a reset is done manually by connecting pins 9–10 on header H4, or when the watchdog timer times out.

If a valid program (created with Dynamic C) has been installed in EPROM, the program starts running. A valid program is recognized by a code that Dynamic C places in the file used to burn the EPROM.

The flowchart in Figure 3-1 shows the startup sequence of the BL1600 after a hardware reset.




Figure 3-1. BL1600 Activity at Startup

Run Mode

Before running a program from battery-backed RAM or flash EPROM, be sure pins 1–2 and 3–4 on header J1 are *not* connected. If a valid user program is already in EPROM, that program will run immediately after a hardware reset.



If the Dynamic C EPROM is present on the board, the BL1600 executes the program stored in battery-backed RAM—that is, the program last run under Dynamic C. If the Dynamic C EPROM has been replaced with a custom EPROM, then the BL1600 executes that program.

EPROM

Programming EPROMs

Dynamic C can be used to create a file for programming an EPROM by selecting the **Compile to File** option in the **COMPILE** menu. The BL1600 must be connected to the PC running Dynamic C during this step because essential library routines must be uploaded from the Dynamic C EPROM and linked to the resulting file. The output is a binary file (optionally an Intel hex format file) that can be used to build an application EPROM. The application EPROM is then programmed with an EPROM programmer that reads either a binary image or the Intel hex format file. The resulting application EPROM can then replace the EPROM that came with the BL1600.

Whenever the Dynamic C EPROM is replaced by a custom EPROM, the BL1600 ignores the program in battery-backed RAM in favor of the program stored in EPROM.

Memory Size

When doing program development with Dynamic C, it is best to use a 128K SRAM or larger. Dynamic C will work with a 32K SRAM, but the total program space will be limited to 16K of root and 16K of extended memory. This is enough for many programs, but it is inconvenient to run out of memory during development. Once a program is burned into EPROM, there is no reason to use SRAM larger than 32K unless the data space is larger than 32K.

The BL1600 can accommodate SRAM and EPROM chips from 32K to 512K, and flash EPROM from 64K to 256K. The memory chips may have 28 or 32 pins, and must be seated in the sockets as shown in Figure 3-2. The location of pin 1 relative to the socket varies, depending on the size of the chip.




Figure 3-2. Placement of 28-pin and 32-pin EPROMs on BL1600

The corresponding jumper settings for header J1 are shown in Figure 3-3.




Figure 3-3. BL1600 Jumper Settings for Different-Sized SRAM and EPROM

Either 28-pin or 32-pin chips may be used.

Copyrights

The Dynamic C library is copyrighted. Place a label containing the following copyright notice on the EPROM whenever an EPROM that contains portions of the Dynamic C library is created.

©1991–1995 Z-World.

Your own copyright notice may also be included on the label to protect your portion of the code.

Z-World grants purchasers of the Dynamic C software and the copyrighted EPROM library permission to copy portions of the EPROM library as described above, provided that the following two conditions are complied with.

1. The resulting EPROM are used only with BL1600 controllers manufactured by Z-World.
2. Z-World's copyright notice is placed on all copies of the EPROM.

Blank



CHAPTER 4: **SYSTEM DEVELOPMENT**

Chapter 4 provides the following information to develop the BL1600 for specific uses.

- BL1600 interfaces
- Dynamic C libraries
- Driver software
- Serial communication
- Direct programming of the serial ports
- Asynchronous serial communication interface

BL1600 Interfaces

Figure 4-1 shows a block diagram of the BL1600.




Figure 4-1. BL1600 Block Diagram

Digital Inputs

The 12 digital inputs, IN00–IN11, accept CMOS levels, which are at a digital threshold of approximately 2.5 V. The digital inputs are arranged in two groups, IN00–IN07 and IN08–IN11, on header H1. Each input line has a 4.7 kΩ pull-up resistor. Figure 4-2 shows the pinout for header H1.




Figure 4-2. BL1600 Digital Inputs Header H1 Pinout



Although the digital inputs are IN00–IN11, the software function calls refer to the channels as channels 1–12.

Digital Outputs

There are 14 digital outputs. The EN485 line can be used as an additional digital output if RS-485 communication is not used—no special jumper settings or software calls have to be made. The SCL line can be used as an additional digital output on the B11610, which has no EEPROM.

The output lines are arranged into two groups.

- OUTB1–OUTB8 — eight 8-bit parallel outputs
- OUT1–OUT6, EN485 and SCL — eight individually selectable lines

The OUTB1–OUTB8 and SCL signals are carried on header H2 as shown in Figure 4-3.

Seven of the digital outputs (OUT1–OUT6 and EN485) feed the high-current driver, providing seven high-current outputs (HC1–HC7) suitable for driving relays, solenoids, or lamps. The high-current outputs are available on header J2 as shown in Figure 4-4.




Figure 4-3. BL1600 Digital Outputs Header H2 Pinout




Figure 4-4. BL1600 Header J2 Pinout

Each high-current output includes a protective diode that can return inductive spikes to the power supply. The diodes use a common bus (“K”). Sinking drivers are the factory default. Sourcing drivers may also be used. Both can be seated in the same 18-pin socket.



See Appendix D, “Sinking and Sourcing Drivers,” for more information on using or changing between sinking and sourcing driver chips.

Serial Ports

Two serial ports support asynchronous communication at baud rates from 300 bps to 57,600 bps. The drivers can be configured either as two 3-wire RS-232 ports or as one 5-wire RS-232 port (with RTS and CTS) and one half-duplex RS-485 port.

Header H3 supports full-duplex RS-232 communication with handshake lines. The RS-485 lines (on the screw terminals, header J2) provide half-duplex asynchronous communication over twisted pair wires up to 3 km.

Figure 4-5 illustrates the pinout on header H3 for RS-232 communication and provides the appropriate RS-232 and RS-485 jumper settings on header J1. Figure 4-4 shows the location of the RS-485 signals on header J2.




Figure 4-5. BL1600 RS-232 Serial Port Header H3 Pinout and Jumper Settings



When header H3 is used as the programming port, it cannot be used as a communication port by the application. Refer to Chapter 2, “Getting Started,” for information on how to program with an XP8700 expansion board if your application will need header H3.

Figure 4-6 shows the configuration of two 3-wire RS-232 channels.




Figure 4-6. BL1600 Configuration for Two 3-wire RS-232 Channels

Figure 4-7 shows the configuration for one 5-wire RS-232 channel and one 2-wire RS-485 channel.





Figure 4-7. BL1600 Configuration for One 5-wire RS-232 Channel and One 2-wire RS-485 Channel

 The high-current output chip, U10, and the RS-485 driver, U9, are coupled, so that disabling the RS-485 driver will also disable the high-current output. The EN485 line may be used as high-current output HC7 if RS-485 communication is not needed.

Miscellaneous Signals

Header H4, shown in Figure 4-8, has three user lines, two DMA request lines, and three miscellaneous signals. These signals are provided to support customer-designed expansion boards for the BL1600. The signals are discussed briefly.




Figure 4-8. BL1600 Miscellaneous Signals Header H4 Pinout

/USER1–/USER3

Coupled with address lines A0–A3, **/USER1–/USER3** allow you to read and write to as many as 48 devices (registers) in your system. Only one line asserts at any one time. Each line identifies a group of registers. The groups have the following base addresses.

/USER1	0x150
/USER2	0x160
/USER3	0x170

A register's address is *group + register#*. For example, to read or write to register 5 of group 2, use address 0x165.

/DREQ0, /DREQ1

These are DMA request lines for Z180 DMA Channels 0 and 1.

/INT2

This interrupt line is available to the designer. (**/INT0** is reserved and **/INT1** is the PLCBus interrupt.)

/RESET

The **/RESET** signal can be used to manually reset the BL1600. A pushbutton reset switch may be added across pins 9 and 10 of H4.

E

The **E** signal is useful for customer-designed expansion boards for the BL1600.



Refer to page 39 of the Zilog *Z180 MPU Users Manual* for more information about using **E**.

PLCBus Port

Header H5 provides the PLCBus signals. The eight data lines on this header can be used as TTL-level inputs and outputs if the PLCBus is not otherwise used.



Refer to Appendix E, “PLCBus,” for more information about the PLCBus.

Dynamic C Libraries

Functions specific to the BL1600 can be found in the software libraries supplied with Dynamic C. These libraries are maintained in source code so they can be easily modified or augmented by the user. The BL1600 functions are in the **BL16XX.LIB**, **CPLC.LIB**, **DRIVERS.LIB**, **AASC.LIB**, and **SERIAL.LIB** libraries.

Whenever unresolved calls to functions remain after an application is compiled, Dynamic C scans all the source libraries for functions with that name. When found, the functions are extracted from the library and are compiled with the application. The libraries are scanned until no more unresolved names are found, so library functions can call other library functions and their order of appearance in the library is not important.

Dynamic C also accesses a library in the EPROM on the BL1600 board. This library is in machine language and the library functions can be called directly from a program. This library has the advantage that the code does not need to be downloaded, reducing the compile time, particularly for the standard version of Dynamic C with its slower communication rate. The EPROM library version is used if the same function appears in both the EPROM library and the source library.

Use the following preprocessor command to replace a function in the EPROM library.

```
#KILL func1, func2, func3 . . .
```

This causes the specified functions in the EPROM library to be ignored. Replaceable functions in the EPROM library have a period (.) in their name. The **KILL** directive will change the period to an underscore (_), causing a search for a legal C name to occur. Your own version of the function can then be added to the program or taken from one of the libraries.

The Dynamic C **SAMPLES\BL16XX** subdirectory provides sample programs to illustrate the software described in this chapter.

Driver Software

Z-World's drivers make it easy to communicate with the BL1600 inputs and outputs. A *direct driver* immediately reads or writes to the controlled hardware. An *indirect driver* uses intermediate variables. Z-World's *virtual driver* (described later in this section under "Virtual Drivers") is a periodically called interrupt service routine that connects the hardware with intermediate variables.

Low-level drivers return, send, or transmit values as received or as presented by the hardware interface. *High-level drivers* modify the inputs or outputs in some way, such as by introducing calibration, hysteresis or averaging. Indirect, high-level drivers eliminate concerns about the technical details of the I/O interface, but the price for this convenience is a slight loss of speed and efficiency.

Digital Inputs

- `int up_digin(int chan)`

Gets the value at the specified digital input channel `chan` (1–12).

RETURN VALUE: 1 when the input voltage is high (>2.5 V) and 0 when the input voltage is low.

Digital Outputs

There are 14 digital outputs, plus two additional outputs (EN485 and SCL) that depend on the hardware. Z-World's driver software library does not provide drivers for the additional outputs. `CPLC.LIB` needs to be modified to use EN485 and SCL as digital outputs.

Outputs 1–8 correspond to the signals OUTB1–OUTB8. Outputs 9–14 correspond to OUT1–OUT6. Outputs 9–14 also feed the high-current driver (HC1–HC6).

Bear in mind that the total number of high-current outputs that can be on at one time is subject to chip power limits and ambient temperature. With the sinking driver (ULN2003), no more than two 500 mA channels per chip should be on continuously. All channels can be on at once as long as they do not consume more than 100 mA per channel. The UDN2985A chips can drive all channels at 30 V and 250 mA per channel at 25°C.

All 14 digital outputs appear on H2. A 0 makes the output on H2 low; a 1 makes it high. For outputs 9–14, a 0 switches the high-current output off and a 1 turns it on. Sinking driver outputs pull low when turned on; sourcing driver outputs pull high.

- `int up_setout(int channel, int value)`

Turns on a digital output. Pass `channel` number (1–14) and `value` (0 for OFF, 1 for ON).

A 0 turns the output off, 1 turns the output on. Digital outputs 9–14 support high-current channels 1–6.

High-Speed DMA Counter

The two DMA channels of the Z180 are used as high-speed counters (up to 500 kHz). Function calls load the countdown value for the DMA channel and enable the DMA interrupt. Once a counter reaches zero, flags for the DMA channel are set to 1. Your program can monitor these flags.

- **void DMA0Count(unsigned integer count)**

Loads DMA Channel 0 with the **count** value and enables the DMA Channel 0 interrupt. The function sets the flag **_DMAFLAG0** to zero. When **count** negative edges have been detected, the channel will cause an interrupt and the interrupt service routine will set the flag **_DMAFLAG0** to 1. A program can monitor **_DMAFLAG0** to determine if the number of counts has occurred.

- **void DMA1Count(unsigned integer count)**

Loads DMA Channel 1 with the **count** value and enables the DMA Channel 1 interrupt. The function sets the flag **_DMAFLAG1** to zero. When **count** negative edges have been detected, the channel will cause an interrupt and the interrupt service routine will set the flag **_DMAFLAG1** to 1. A program can monitor **_DMAFLAG1** to determine if the number of counts has occurred.

- **unsigned integer DMASnapShot(byte channel, unsigned integer *counter)**

Reads the number of pulses that a DMA channel (0 or 1) has counted. A DMA counter is initialized with one of the two preceding functions. If a DMA channel is counting too fast to allow for stable reading of the count value, the function returns 0. If the function reads a stable count value, it returns 1 and sets the parameter **count**. Note that even if you are unable to read the counts, DMA interrupts will still occur when the DMA channel counts down from its loaded value.

Sample DMA Counter Program

```
main(){
    unsigned integer count, oldcount;
    oldcount = 0;
    DMA0Count( 100 );    // count 100 pulses
    while( !DMA0FLAG ){ // not finished
        if( DMASnapShot(0,&count) ){ // is it stable?
            if( oldcount != count ){
                oldcount = count;
                printf( "DMA counted %u\n", count );
            }
        }
    }
    printf( "finished counting\n" );
}
```

GENDMA.C in the **SAMPLES\BL16XX** directory illustrates the use of DMA functions.

Battery-Backed Clock

The battery-backed clock retains the time and date with a resolution of one second, and an accuracy of about one second per day. It automatically accounts for leap year.

The following structure is used to hold the time and date:

```
struct tm {
    char tm_sec;           // 0-59
    char tm_min;          // 0-59
    char tm_hour;         // 0-23
    char tm_mday;         // 1-31
    char tm_mon;          // 1-12
    char tm_year;         // 0-150 (1900-2050)
    char tm_wday;         // 0-6 where 0 means Sunday
};
```

The following routines are used to read and write the clock.

```
int tm_wr( struct tm *x ); // write the clock
int tm_rd( struct tm *x ); // read the clock
```

The following routines convert the time to and from a long integer. The long-integer format represents the number of seconds that have passed since January 1, 1980 at midnight (00:00:00).

```
// return long seconds from structure
long mktime( struct tm *t );

// return structure from long seconds
int mktime( struct tm *t, long time );
```

The long-integer format is convenient for comparing dates and times. The **mktime** function correctly handles dates beyond the year 2000.

Writing to Flash EPROM

- **int WriteFlash(unsigned long addr, char* buf, int num)**

Writes **num** bytes from **buf** to flash EPROM, starting at **addr**. **addr** is an absolute physical address.

To do this, allocate flash data in the Dynamic C program by declaring initialized variables or arrays, or by initialized **xdata**. For **xdata**, pass the data name directly to the following function.

```
xdata my_data { 0, 0xFF, 0x08 };
...
WriteFlash( my_data, my_buffer, my_count );
```

For normal data, pass the physical address of the data to the following function.

```
char xxx[] = { 0, 0xFF, 0x08 };  
...  
WriteFlash( phy_adr(xxx), my_buffer, my_count );
```

RETURN VALUE:

- 0 if the operation was successful.
- 1 if no flash EPROM is present.
- 2 if a physical address is within the BIOS area (low 8K).
- 3 if a physical address is within the symbol table.
- 4 if the write times out.

The data must be initialized when it is declared, otherwise it will be placed in RAM, not ROM, and this function will not work.



Writing to flash EPROM, in essence, treats the flash memory as a **nonvolatile** memory. The flash EPROM is rated for 10,000 writes. In tests, the flash EPROM has lasted at least 100,000 writes. Nevertheless, there is a limit, after which the flash EPROM will increasingly fail to accept a write.

Virtual Drivers

Z-World supports application development for the BL1600 in a variety of ways. Some of this support stems from a virtual driver that monitors the BL1600's ports and provides a set of "virtual" latches, timers, counters, and function keys.

The virtual drivers are a software package that is activated by a periodic interrupt (every 25 ms) and provides certain services to the application programmer.

These services include the following.

- Run real-time second and millisecond clocks
- Scan the digital inputs and setting digital outputs
- Provide any number of "virtual" watchdog timers
- Provide clock drive for the optional real-time kernel
- Provide up to 10 software timers
- Support **DelayMs** and **DelaySec** for costatements.

The following function call in the **BL16XX.LIB** library initializes the virtual I/O.

- **void VIOInit();**

Initializes virtual I/O. This dummy function is used as a host for the global initialization of the virtual I/O variables. Virtual inputs are read and virtual outputs are written whenever **VIODrvr()** is called. The inputs are DIGIN1 to DIGIN16, and the outputs are OUT1 to OUT16. Two inputs have to be same for two consecutive reads in order to be valid.

- **void VIODrvr();**

This virtual I/O driver updates the virtual inputs DIGIN1 to DIGIN16. The virtual outputs OUT1 to OUT16 are sent to their corresponding output ports.

The following switches turn off services of the virtual driver. If used, they must precede driver calls. To avoid disabling the service, leave the switch undefined.

- **#define NOTIMERS**

Disables the virtual timers. The virtual timers are software timers, useful in ladder logic programming.

The following preprocessor variables control features of the virtual driver.

- **#define N_WATCHDOG *nn***

Specifies the number of virtual watchdog timers. Each virtual watchdog has a counter that has to be reloaded. If the counter for any virtual watchdog counts down to zero, a hardware reset is forced. Use

```
up_wdoghit( int watchdog, byte count )
```

where **count** is the number of ticks (25 ms) to countdown, to reload a virtual watchdog. You can monitor a virtual watchdog **wdog**, if necessary, by reading the internal variable **lc_wdogarray[wdog-1]**.

The program **VWDOG.C** in the **SAMPLES\CPLC** subdirectory illustrates the use of virtual watchdog timers.

- **#define RUNKERNEL**

Requests the real-time kernel. It will be initialized.

Invoking the Virtual Driver

To invoke the virtual driver, call `uplc_init` from your main function. The `uplc_init` function will initialize the following items.

- Variables for the virtual driver
- Virtual watchdog timers (if requested)
- The real-time kernel (if requested)
- The timer that runs the background routine.

If you do not use `uplc_init`, your program must periodically hit the hardware watchdog (if it is enabled by connecting pins 27–28 on header J1). Otherwise, the BL1600 will reset approximately once every second.

Virtual Driver Variables

The variables described in this section are defined in the `CPLC.LIB` library. The virtual driver updates input variables every 25 ms to reflect the state of the hardware inputs, and also sets hardware outputs based on the state of its output variables.

The virtual driver does not change input variables unless the hardware input has the same value for at least 2 consecutive ticks of the virtual driver.

Digital Inputs

Once `uplc_init` is called, the virtual driver references the 12 variables `DIGIN1`, `DIGIN2`, `DIGIN3`, `DIGIN4`, ..., `DIGIN10`, `DIGIN11`, `DIGIN12` that represent the 12 digital inputs. For example,

```
heater = DIGIN1 || DIGIN12;
```

These variables take the value 1 if the input is high (>2.5 V) and 0 if the input is low. The parameter value is changed only if the new value remains the same for 2 ticks (25 ms to 50 ms) of the virtual driver.

Digital Outputs

Sets the variables `OUTB1`, `OUTB2`, ..., `OUTB7`, `OUTB8` for digital outputs to a value of 0 for a low level, or to a value of 1 for a high level. Sets the variables `HC1`, `HC2`, ..., `HC5`, `HC6` for high-current outputs to a value of 0 to turn off the high-current output (on the screw terminals, header J2), or to a value of 1 to turn on the output. Sinking driver outputs pull low when on; sourcing driver outputs pull high.


Timers

There are 10 virtual timers. Each timer has an input flag, an output flag, and a reload value as follows.


T1I, T2I, ..., T10I input flags
T1O, T2O, ..., T10O output flags
T1RLD, T2RLD, ..., T10RLD reload values

When a timer input (e.g., T1I) goes from 0 to 1, the counter starts counting down from the reload value (e.g., T1RLD), one count every virtual driver tick (25 ms). When the count reaches zero, the output flag (T1O) is set to 1. Whenever the input is set to zero, the output flag is forced to zero. If the input goes to zero before the counter expires, nothing happens to the output. It stays at 0. Figure 4-9 shows the behavior of the output flags for both counter scenarios.

The virtual timers are implemented in software and do not correspond to any BL1600 hardware.



(a) Input Drops to 0 After Counter Reaches 0



(b) Input Drops to 0 Before Counter Reaches 0

Figure 4-9. Output Flag as Timer Counts Down

Serial Communication

RS-232 Communication

Z-World has RS-232 support libraries for the Z180's Ports 0 and 1, and for the XP8700 expansion board. Functional support for serial communication includes the following.

- Initialization of the serial ports.
- Monitoring and reading a circular receive buffer.
- Monitoring and writing to a circular transmit buffer.
- An echo option.
- CTS (clear to send) and RTS (request to send) control.
- XMODEM protocol for downloading and uploading data.
- A modem option.

Receive and Transmit Buffers

Serial communication is made easier with a background interrupt routine that updates receive and transmit buffers. Every time a port receives another character, the interrupt routine places it into the receive buffer. Your program can read the data one character at a time or as a stream of characters terminated by a special character.

A program sends data by writing characters into the transmit buffer. If the serial port is not already transmitting, the write functions will automatically initiate transmission. Once the last character of the buffer is sent, the transmit interrupt is turned off. Data can be written one character at a time or as a stream of characters.

Echo Option

If the echo option is turned on during initialization of the serial port (with `Dinit_z0`, `Dinit_z1`, or `Dinit_uart`) any character received is automatically echoed back (transmitted out). This feature is ideal for use with a dumb terminal and also for checking the characters received.

CTS/RTS Control

Z180 Port 0 is constrained by hardware to have the CTS (clear to send) pulled low by the RS-232 device to which it is talking. An XP8700, however, can enable or disable the effect of the CTS line. Z180 Port 1 does not support the CTS/RTS lines.

If you choose the CTS/RTS option, the support software will pull the RTS (request to send) line high when the receive buffer has reached 80% of its capacity. Thus, the transmitting device (if its CTS is enabled) will stop transmitting. The RTS line is pulled low again when the received buffer has gone below 20% of its capacity.

If the device with which the BL1600 is communicating does not support CTS and RTS, the CTS and RTS lines on the BL1600 side can be tied together to make communication possible.

The CTS line (/CTS0) is grounded when not in use.

XMODEM File Transfer

The BL1600 supports the XMODEM protocol for downloading and uploading data. Currently, the library supports downloading an array of data whose size is a multiple of 128 bytes.

Uploaded data are written to a specified area in RAM. The targeted area for writing should not conflict with the current resident program or data.

Character echo is automatically suspended during XMODEM transfer.

Modem Communication

Using modems and telephone lines allows RS-232 communication across great distances. If you choose the modem option, character streams that are read from the receive buffer are automatically scanned for modem commands. When a modem command is found, the software takes appropriate action. Normally, the communication package would be in COMMAND mode while waiting for valid modem commands or messages. Once a link is established, communication is in DATA mode (regular RS-232). However, the software continues to monitor the modem for a **NO_CARRIER** message.

The software assumes that modem commands are terminated with **<CR>**, that is, a carriage return (0x0D). The modem option is easiest to use when the user protocol also has **<CR>** as the terminating character. Otherwise, the software has to check for two different terminating characters. The user's terminating character cannot be any of the ASCII characters used in modem commands nor can it be a line-feed character.

The RS-232 library supports communication with a Hayes Smart Modem or compatible modem. The CTS, RTS and DTR lines of the modem are not used. If the modem used is not truly Hayes Smart Modem compatible, the CTS, RTS and DTR lines on the modem side need to be tied together. The CTS and RTS lines on the BL1600 side also have to be tied together. A NULL connection is also required for the TX and RX lines. A commercial NULL modem would already have its CTS and RTS lines tied together on both sides.

Software Support

This section describes functions for Port 0 of the Z180. Similar functions are available for the XP8700 expansion card. For the XP8700, substitute “**uart**” for “**z0**” in the function name. For Z180 Port 1, substitute “**z1**” for “**z0**” in the function name. For example, the initialization routine for Z180 Port 0 is called `Dinit_z0`. The equivalent function for the XP8700 would be `Dinit_uart` and the equivalent function for Z180 Port 1 would be `Dinit_z1`.



Refer to the *XP8700 and XP8800 User's Manual* for more information on the XP8700 expansion board.

Interrupt Handling for Z180 Port 0

Normally, a serial interrupt service routine would be declared with the following compiler directive.

```
#INT_VEC SER0_VEC routine
```

However, if you use the same serial port for Dynamic C programming, your program has to be downloaded first with Dynamic C before the address of the serial interrupt service routine is loaded into the interrupt vector table. That is, the service routine must be loaded at run-time. The function

```
reload_vec( int vector, int(*serv_function)() )
```

will load the address of the service function into the specified location in the interrupt vector table. In this case, do not use the `#INT_VEC` directive. Once your service routine has taken over, Dynamic C cannot be used to debug your program.

When executable programs are generated for EPROM or for download to RAM, there will be no need for communication with Dynamic C. Then, the compile-time directive `#INT_VEC` can be used freely.

RS-232 Software Support

- `int Dinit_z0 (void *rbuf, void *tbuf,
 int rsize, int tsize,
 byte mode, byte baud,
 byte modem, byte echo);`

Initializes Z180 Port 0 for communication.

PARAMETERS: **rbuf** is a pointer to the receive buffer.

tbuf is a pointer to the transmit buffer.

rsize is the size of the receive buffer.

tsize is the size of the transmit buffer.

mode selects the operation mode as follows.

bit 0	0	1 stop bit
	1	2 stop bits
bit 1	0	no parity
	1	with parity
bit 2	0	7 data bits
	1	8 data bits
bit 3	0	even parity
	1	odd parity
bit 4	0	CTS, RTS disabled
	1	CTS, RTS enabled

baud is the baud rate in multiples of 1200 (e.g., specify 8 for 9600 bps).

modem 1—modem is supported; 0—no modem.

echo 1—every character is echoed; 0—no echo.

If CTS/RTS handshaking is selected, transmission from the sender is disabled (by raising RTS) when the receive buffer is 80% full. The software lowers RTS (enabling the sender to transmit) when the receive buffer falls below 20% of capacity. In a similar manner, a remote system can prevent transmission of data by Z180 Port 0 by asserting its RTS (connected to the Z180 Port 0 CTS).

- `int Dread_z01ch(char *ch)`

Reads a character from the circular receive buffer into character **ch**.

RETURN VALUE: 0—buffer empty; 1—byte has been successfully extracted from buffer.

- **int Dwrite_z01ch(char ch)**
Places a character in the transmit buffer. If the serial port is not already transmitting, the function initiates transmission.
RETURN VALUE: 0—transmit buffer did not have space for **ch**;
1—write was successful.
- **int Dread_z0(char *buffer, char terminate)**
Checks the receive buffer for a message terminated with the character **terminate**. The message is copied to the buffer and is terminated with a null character according to the C convention.
RETURN VALUE: 0—no message found with the specified terminating character; 1—message has been successfully extracted from buffer.
- **int Dwrite_z0(char *buffer, int count)**
Copies **count** bytes from **buffer** to the transmit buffer. If the serial port is not already transmitting, the function initiates transmission.
RETURN VALUE: 0—transmit buffer did not have space for **count** bytes; 1—write is successful.
- **void Dz0send_prompt()**
Places CR, LF7 Tc in the transmit buffer.
- **void Dreset_z0rbuf()**
Resets the receive buffer.
- **void Dreset_z0tbuf()**
Reset the transmit buffer7 Tc to stop transmission.
- **void Dkill_z0()**
Resets Z180 Port 0.
- **void z0binaryreset()**
Sets the serial communication mode to regular ASCII mode. This means that the backspace character is tracked.
- **void z0binaryset()**
Sets the serial communication mode to binary. This means that all data received are placed directly to the receive buffer without preprocessing.

XMODEM Commands

- **int Dxmmodem_z0down(char *buffer, int count)**

Sends (downloads) **count** 128-byte blocks in buffer using XMODEM protocol.

RETURN VALUE:

0—timed out (no transfer).

1—successful transfer.

2—canceled transfer (canceled by receiver side).

- **int Dxmmodem_z0up (unsigned long address, int *pages, int dest, int(*parser)())**

Receives (uploads) a file using XMODEM protocol.

PARAMETERS: **address** is the physical address in RAM where the received data are to be stored. If the receive buffer is allocated by **xdata** (a Dynamic C keyword to allocate extended memory data), then the name of the array may be used for the **address** argument. If, however, the data area is allocated using “normal” C, the logical address of the buffer must first be converted to a physical address using the library function **phy_adr**.

pages is the number of 4K blocks of data that have been transferred.

dest If an RS-485 master-slave network is set up, specify **dest** = 0 when the upload is intended for the master. If **dest** is non-zero, the upload is intended for the designated slave.

parser is the function that handles parsing of the uploaded data.

RETURN VALUE:

0—timed out (no transfer).

1—successful transfer.

2—canceled transfer (canceled by sender side).

- **int z0modemset ()**

Returns information about modem selection.

RETURN VALUE: 1 if the modem option is selected (with **Dinit_z0**), and 0 if not.

- **int z0modemstat ()**

Returns the status of the modem.

RETURN VALUE: 1 if the modem is in command mode, and 0 if it is in data mode.

Miscellaneous Functions

- **int Dget_modem_command()**

Deciphers Hayes-compatible modem command.

These are the modem commands.

```
0  "\nOK"           // okay respond
1  "\nCONNECT"     // connect at 300 bps
2  "\nRING"       // ring detected
3  "\nNO CARRIER" // no carrier
4  "\nERROR"      // command error
5  "\nCONNECT 1200" // connect at 1200 bps
6  "\nNO DIALTONE" // no dial tone
7  "\nBUSY"       // line busy
8  "\nNO ANSWER"  // no answer
9  "\nCONNECT 2400" // connect at 2400 bps
10 "\n"           // just a line feed
```

A Hayes Smart Modem (or compatible) is recommended. A NULL modem is needed between the BL1600 and the modem.

Some modems may require that the RTS(4), CTS(5) and DTR(20) lines on the modem side be tied together.

A NULL modem is not needed between COM1 and COM2 and external modems.

RETURN VALUE: -1 if no modem command is matched.

- **void Drestart_z0modem()**

Restarts the modem (during start of program or abnormal operation).

- **void Dz0modem_chk(char *buffer)**

Checks **buffer** for valid modem commands. The function takes the appropriate response to the modem command if it finds a valid modem command.

RETURN VALUE: 0—valid modem command; -1—invalid modem command.

- **void Dz0_circ_int()**

Interrupt service routine for Z180 Port 0.

- **void Ddelay_1sec()**

Creates a 1-second delay (approximately). If **RUNKERNEL** is defined, **suspend(40)** is used.

- **void Ddelay_100ms()**

Creates a 100 ms delay (approximately).

- **void reload_vec(int vector,
int (*function) ())**

Loads the address of a function into the interrupt vector table.

This function is only useful during program development when Z180 Port 0 is used as the Dynamic C programming port. The compile-time interrupt directive loads the serial service function's address in the interrupt vector table to generate the executable code for the EPROM or for download to RAM.

PARAMETERS: **vector** is the offset for the specific interrupt.

function is a pointer to the interrupt service function.

- **int getcrc(char *buffer, byte count, int accum)**

Computes the CRC (cyclic redundancy check, or check sum) for data in **buffer**. Calls to **getcrc** can be concatenated to compute the CRC for a large buffer.

PARAMETERS: **buffer** contains the characters for which to compute the CRC.

count is the number of characters in **buffer**, limited to 255, for this function.

accum is the accumulated CRC value from previous computation.

RETURN VALUE: the integer CRC value.

- **void resetZ180int()**

General reset function that resets, or disables, interrupts for DMA channels, Z180 serial channels 0 and 1, PRT timers, CSI/O, INT1 and INT2.

Master-Slave Networking

Dynamic C contains library functions for master-slave two-wire half-duplex RS-485 9th-bit binary communication. This protocol is supported only on Z180 Port 1, which can be configured for RS-485 communication (see Figure 4-5 on page 4-4). Any Z-World controller with an RS-485 serial port can be the master or the slave. There can only be one master, with a board identification address of 0. Slaves each have their own distinct identification number from 1 to 255.

Functional support for master-slave serial communication follows this scheme:

- Z180 Port 1 is initialized for RS-485 communication.
- The master sends an inquiry and waits for a response from a slave.
- Slaves monitor for their address during the 9th-bit transmission. The targeted slave replies to the master.

The binary command message protocol adopted is similar to that used for the opto 22 binary protocol. A master message has this form.

[**slave id**] [**len**] [] []...[] [**CRC hi**][**CRC lo**]

The slave's response has this form.

[**len**] [] []...[] [**CRC hi**] [**CRC lo**]

The term **len** is the length of the message that follows. **len** does not include the **slave id** byte (if it is part of the message) or the two CRC bytes. The CRC bytes include the **slave id** byte (if it is part of the message) and the **len** byte.

During a transfer from the master, the address byte is transferred in 9th-bit address mode, and only the slave that matches this address will listen to the rest of the message, which is sent in regular 8-bit data mode.

RS-485 Network Hardware Connections

Figure 4-10 and Figure 4-11 show the connections for a two-wire RS-485 network. Remove RP2, shown in Figure 4-12, from all BL1600 controllers in the network, except the BL1600 that is the master controller. RP2 contains the bias and termination resistors. Add a 220 Ω termination resistor to the end BL1600 as shown in Figure 4-12.




Figure 4-10. RS-485 Multidrop Network




Figure 4-11. RS-485 Networking Among Z-World Controllers




Figure 4-12. Installation of Termination and Bias Resistors

RS-485 Network Software Support

- `void op_init_z1(char baud, char *rbuf, byte address)`

Initializes Z180 Port 1 for RS-485 9th-bit binary communication. The data format defaults to 8 bits, no parity, 1 stop bit.

PARAMETERS: **baud** selects the baud rate in multiples of 1200 bps (specify 16 for 19,200 bps).

rbuf is the receive buffer.

address is the network address of the board: 0 for the master board. 1–255 for slaves.

- `int check_opto_command()`

Checks for a valid and completed command or reply in the receive buffer.

RETURN VALUE:

0 if there is no completed command or message available.

–1 if there is a completed command or reply available.

–2 if the completed command or reply has a bad CRC check.

- `int sendOp22(byte dest, char *message, byte len, int delays)`

Sends a message to the slave and waits for a reply. The function puts the message in the following format.

`[slave id] [len+2] [] []...[] [CRC hi][CRC lo]`

PARAMETERS: **dest** is the slave destination (1–255).

message is the message.

len is the length of the message not including the two CRC bytes. The maximum message length is 251 bytes.

delays is the number of delays to wait for the slave reply. Each delay is ~50 ms if the real-time kernel (RTK) is used. If the RTK is not used, the software-generated delay is approximately 50 ms.

RETURN VALUE:

–1 if there is no reply from the slave.

–2 if a completed reply has a bad CRC.

1 if there is a completed reply with a proper CRC.

The slave's reply is stored in the receive buffer initialized with `op_init_z1()`.

- `void replyOpto22(char *reply, byte count,
int delays)`

The slave replies to the master's inquiry. The function puts the reply in the following format.

`[count+2] [] [] ... [] [CRC hi] [CRC lo]`

PARAMETERS: **reply** is the slave's reply string.

count is the length of the reply not including the two CRC bytes. Because two CRC bytes are appended at the end, the longest reply is 252 bytes.

delays is the number of delays before the message is transmitted

- **void op_kill_z1()**
Turns off Z180 Port 1 and disables the RS-485 driver.
- **void z1_op_int()**
Interrupt service routine for Z180 Port 1 used in master-slave networking.

Support Libraries and Sample Programs

Table 4-1 lists the libraries in the Dynamic C **LIB** subdirectory that support serial communication.

Table 4-1. Dynamic C Serial Communication Libraries

Library	Description
AASC.LIB	Abstract Application-Level Serial Communication set of libraries for all Z-World controllers.
Z0232.LIB	RS-232 library for Z180 Port 0.
Z1232.LIB	RS-232 library for Z180 Port 1.
MODEM232.LIB	Miscellaneous functions common to other communication libraries.
UART232.LIB	RS-232 library for the XP8700.
NETWORK.LIB	RS-485 9-bit binary half-duplex support for Z180 Port 1.

Table 4-2 lists Dynamic C **SAMPLES\NETWORK** subdirectories with sample programs to illustrate the use of the various serial communication functions.

Table 4-2. Dynamic C Sample Serial Communication Programs

Sample Program	Description
CZ0REM.C Z0REM.C	Sample master program using Z180 Port 0 as the RS-232 communication port.
CSREMOTE.C SREMOTE.C	Sample slave program, talks with the master running with CZ0REM.C (Z0REM.C).
RS232.C	Simple RS-232 sample program.
Z1232.C	Simple RS-232 sample program for Z180 Port 1.
RS485.C	Simple slave program to talk with a running master.
UART232.C	Simple RS-232 sample program using the XP8700.
CUARTREM.C UARTREM.C	Same program as CZ0REM.C or Z0REM.C , but it uses an XP8700 as the RS-232 communication port.

Direct Programming of the Serial Ports

If you are planning to use the serial ports extensively, or if you intend to use synchronous communication, Z-World recommends that you obtain copies of the Zilog technical manuals, available from Zilog, Inc., in Campbell, California. You will need the **Z180 MPU User's Manual** and the **Z180 SIO Microprocessor Family User's Manual** (which describes the CPU and CTC, DMA, PIO and SIO functions). Z-World provides two low-level utility functions to get you started.

- `int sysclock()`
- `int z180baud(int clock, int baud)`

The `sysclock` function returns the clock frequency in multiples of 1200 bps as read from the EEPROM. The clock frequency was stored at location 108H at the factory. The `z180baud` return value is an integer whose least significant byte is stored in CNTLB0 or CNTLB1, considering only the bits needed to set the baud rate. You must supply the clock and baud rate in multiples of 1200 Hz. Thus, a 9.216 MHz clock is expressed by 7680 and 19,200 bps is represented by 16. The return value is -1 if the baud value cannot be derived from the given clock frequency.

Each serial port appears to the CPU as a set of registers. You can access each serial port directly with the `inport` and `outport` library functions, using the symbolic constants for addresses 0x00-0x09.



The symbolic constants for addresses 0x00-0x09 are listed in Table G-3, Appendix G, "Memory, I/O Map, and Interrupt Vectors."

The following sample code shows how to read and write from Z180 Port 0.

```
char ch;  
ch = inport( RDR0 );  
outport( TDR0, ch );
```

Ports may be polled or interrupt-driven. The interrupt vectors are `SER0_VEC` for Z180 Port 0, and `SER1_VEC` for Z180 Port 1.



Appendix G, "Memory, I/O Map, and Interrupt Vectors," provides further information about interrupt vectors.

Attainable Baud Rates

The serial ports built into the Z180 can generate standard baud rates with a 9.216 MHz clock. (The crystal is 18.432 MHz.)

Z180 Serial Ports

The Z180 has two independent, full-duplex asynchronous serial channels, with a separate baud rate generator for each channel. The baud rate can be divided down from the microprocessor clock or from an external clock for either or both channels.

The serial ports have a multiprocessor communication feature that can be enabled. When enabled, an extra bit is included in the transmitted character (where the parity bit would normally go). Receiving Z180s can be programmed to ignore all received characters except those with the extra multiprocessing bits enabled. This provides a 1-byte attention message that can be used to wake up a processor without the processor having to monitor (intelligently) all traffic on a shared communication link.

The block diagram in Figure 4-13 shows Serial Channel 0. Serial Channel 1 is similar, but modem control lines /RTS and /DCD do not exist. The five unshaded registers shown in Figure 4-13 are directly accessible as internal registers.




Figure 4-13. Z180 Serial Channel 0

The serial ports can be polled or interrupt-driven.

A *polling* driver tests the ready flags (**TDRE** and **RDRF**) until a ready condition appears (transmitter data register empty or receiver data register full). If an error condition occurs on receive, the routine must clear the error flags and take appropriate action, if any. If the **/CTS** line is used for flow control, transmission of data is automatically stopped when **/CTS** goes high because the **TDRE** flag is disabled. This prevents the driver from transmitting more characters because it thinks the transmitter is not ready. The transmitter will still function with **/CTS** high, but exercise care since **TDRE** is not available to synchronize loading the data register (**TDR**) properly.

An *interrupt-driven* driver works as follows. The program enables the receiver interrupt as long as the program wants to receive characters. The transmitter interrupt is enabled only while characters are waiting in the output buffer. When an interrupt occurs, the interrupt routine must determine the cause: receiver data register full, transmitter data register empty, receiver error, or **/DCD0** pin high (channel 0 only). None of these interrupts is edge-triggered. Another interrupt will occur immediately if interrupts are re-enabled without disabling the condition causing the interrupt. The signal **/DCD0** needs special attention because it cannot be disabled while the receive interrupts are on. The **/DCD0** line on the BL1600 is grounded to take it out of the picture.

Asynchronous Serial Communication Interface (ASCI)

The Z180 incorporates an ASCI interface that supports two independent full-duplex channels.

ASCI Status Registers

A status register for each channel provides information about the state of each channel and allows interrupts to be enabled and disabled.

STAT0 (04H)

7	6	5	4	3	2	1	0
RDRF	OVRN	PE	FE	RIE	/DCD0	TDRE	TIE
R	R	R	R	R/W	R	R	R/W

STAT1 (05H)

7	6	5	4	3	2	1	0
RDRF	OVRN	PE	FE	RIE	CTS1E	TDRE	TIE
R	R	R	R	R/W	R	R	R/W

/DCD0 (Data Carrier Detect)

This bit echoes the state of the **/DCD0** input pin for Channel 0. However, when the input to the pin switches from high to low, the data bit switches low only after STAT0 has been read. The receiver is held reset as long as the input pin is held high. This function is not generally useful because an interrupt is requested as long as **/DCD0** is a 1. This forces the programmer to disable the receiver interrupts to avoid endless interrupts. A better design would cause an interrupt only when the state of the pin changes. In the BL1600, this pin is tied to ground.

TIE (Transmitter Interrupt Enable)

This bit masks the transmitter interrupt. If set to 1, an interrupt is requested whenever TDRE is 1. The interrupt is not edge-triggered. Set this bit to 0 to stop sending. Otherwise, interrupts will be requested continuously as soon as the transmitter data register is empty.

TDRE (Transmitter Data Register Empty)

A 1 means that the channel is ready to accept another character. A high level on the **/CTS** pin forces this bit to 0 even though the transmitter is ready.

CTS1E (CTS Enable, Channel 1)

The signals RXS and CTS1 are multiplexed on the same pin. A 1 stored in this bit makes the pin serve the CTS1 function. A 0 selects the RXS function. (The pin RXS is the CSI/O data receive pin.) When RXS is selected, the CTS line has no effect. It is not advisable to use the CTS1 function on the BL1600 because the RXS line is needed to control several other devices on the board.

RIE (Receiver Interrupt Enable)

A 1 enables receiver interrupts and 0 disables them. A receiver interrupt is requested under any of the following conditions: **/DCD0** (channel 0 only), RDRF (read data register full), OVRN (overflow), PE (parity error), and FE (framing error). The condition causing the interrupt must be removed before the interrupts are re-enabled, or another interrupt will occur. Reading the receiver data register (RDR) clears the RDRF flag. The EFR bit in CNTLA is used to clear the other error flags.

FE (Framing Error)

A stop bit was missing, indicating scrambled data. This bit is cleared by the EFR bit in CNTLA.

PE (Parity Error)

Parity is tested only if MOD1 in CNTLA is set. This bit is cleared by the EFR bit in CNTLA.

OVRN (Overflow Error)

Overflow occurs when bytes arrive faster than they can be read from the receiver data register. The receiver shift register (RSR) and receiver data register (RDR) are both full.

RDRF (Receiver Data Register Full)

This bit is set when data is transferred from the receiver shift register to the receiver data register. It is set even when one of the error flags is set, in which case defective data are still loaded to RDR. The bit is cleared when the receiver data register is read, when the **/DCD0** input pin is high, and by RESET and IOSTOP.

ASCII Control Register A

Control Register A affects various aspects of the asynchronous channel operation.

CNTLA0 (00H)

7	6	5	4	3	2	1	0
MPE	RE	TE	/RTS0	MPBR/ EFR	MOD2	MOD1	MOD0
R/W	R/W	R/W	R/W	R/W	R/W	R/W	R/W

CNTLA1 (01H)

7	6	5	4	3	2	1	0
MPE	RE	TE	CKA1D	MPBR/ EFR	MOD2	MOD1	MOD0
R/W	R/W	R/W	R/W	R/W	R/W	R/W	R/W

MOD0–MOD2 (Data Format Mode Bits)

MOD0 controls stop bits: 0 \Rightarrow 1 stop bit, 1 \Rightarrow 2 stop bits. If 2 stop bits are expected, then 2 stop bits must be supplied.

MOD1 controls parity: 0 \Rightarrow parity disabled, 1 \Rightarrow parity enabled. (See PEO in the ASCII Control Register B section for even/odd parity control.)

MOD2 controls data bits: 0 \Rightarrow 7 data bits, 1 \Rightarrow 8 data bits.

MPBR/EFR (Multiprocessor Bit Receive/Error Flag Reset)

Reads and writes on this bit are unrelated. Storing a byte when this bit is 0 clears all the error flags (OVRN, FE, PE). Reading this bit obtains the value of the MPB bit for the last read operation when the multiprocessor mode is enabled.

/RTS0 (Request to Send, Channel 0)

Store a 1 in this bit to set the RTS0 line from the Z180 high. This line is further inverted by the output driver. This bit is essentially a 1-bit output port without other side effects.

CKA1D (CKA1 Disable)

This bit controls the function assigned to the multiplexed pin (CKA1/–TEND0): 1 \Rightarrow –TEND0 (a DMA function) and 0 \Rightarrow CKA1 (external clock I/O for channel 1 serial port).

TE (Transmitter Enable)

This bit controls the transmitter: 1 \Rightarrow transmitter enabled, 0 \Rightarrow transmitter disabled. When this bit is cleared, the processor aborts the operation in progress, but does not disturb TDR or TDRE.

RE (Receiver Enable)

This bit controls the receiver: 1 \Rightarrow enabled, 0 \Rightarrow disabled. When this bit is cleared, the processor aborts the operation in progress, but does not disturb RDRF or the error flags.

MPE (Multiprocessor Enable)

This bit (1 \Rightarrow enabled, 0 \Rightarrow disabled) controls the multiprocessor communication mode which uses an extra bit for selective communication when a number of processors share a common serial bus. This bit has effect only when MP in ASCII Control Register B is set to 1. When this bit is 1, only bytes with the MP bit on will be detected. Others are ignored. If this bit is 0, all bytes received are processed. Ignored bytes do not affect the error flags or RDRF.

ASCII Control Register B

Control register B configures the multiprocessor mode, parity and baud-rate selection for each channel.

CNTLB0 (02H) and CNTLB1 (03H)

7	6	5	4	3	2	1	0
MPBT	MP	/CTS PS	PEO	DR	SS2	SS1	SS0
R/W	R/W	R/W	R/W	R/W	R/W	R/W	R/W

SS (Source/Speed Select)

Coupled with the prescaler (PS) and the divide ratio (DR), the SS bits select the source (internal or external clock) and the baud-rate divider, as shown in Table 4-3.

Table 4-3. Baud Rate Divide Ratios for Source/Speed Select Bits

SS2	SS1	SS0	Divide Ratio
0	0	0	$\div 1$
0	0	1	$\div 2$
0	1	0	$\div 4$
0	1	1	$\div 8$
1	0	0	$\div 16$
1	0	1	$\div 32$
1	1	0	$\div 64$
1	1	1	external clock

The prescaler (PS) the divide ratio (DR) and the SS bits form a baud-rate generator, as shown in Figure 4-14.




Figure 4-14. Baud-Rate Generator

DR (Divide Ratio)

This bit controls one stage of frequency division in the baud-rate generator. If 1, then divide by 64. If 0, then divide by 16. This is the only control bit that affects the external clock frequency.

PEO (Parity Even/Odd)

This bit affects parity: 0 \Rightarrow even parity, 1 \Rightarrow odd parity. It is effective only if MOD1 is set in CNTLA (parity enabled).

–CTS/PS (Clear to Send/Prescaler)

When read, this bit gives the state of external pin **/CTS**: 0 \Rightarrow low, 1 \Rightarrow high. When the **/CTS** pin is high, RDRF is inhibited so that incoming receive characters are ignored. When written, this bit has an entirely different function. If a 0 is written, the baud rate prescaler is set to divide by 10. If a 1 is written, it is set to divide by 30.

MP (Multiprocessor Mode)

When this bit is set to 1, the multiprocessor mode is enabled. The multiprocessor bit (MPB) is included in transmitted data:

start bit, data bits, MPB, stop bits

The MPB is 1 when MPBT is 1 and 0 when MPBT is 0.

MPBT (Multiprocessor Bit Transmit)

This bit controls the multiprocessor bit (MPB). When the MPB is 1, transmitted bytes will get the attention of other units listening only for bytes with MPB set.

Table 4-4 relates ASCII Control Register B to the baud rate. The Z180 in the BL1600 has a 9.216 MHz clock.

Table 4-4. Baud Rates for ASCII Control Register B

ASCII Control Register B Value	Baud Rate at 9.216 MHz (bps)	ASCII Control Register B Value	Baud Rate at 9.216 MHz (bps)
00	57,600	20	19,200
01	28,800	21	9600
02 or 08	14,400	22 or 28	4800
03 or 09	7200	23 or 29	2400
04 or 0A	3600	24 or 2A	1200
05 or 0B	1800	25 or 2B	600
06 or 0C	900	26 or 2C	300
0D	450	2D	150
0E	225	2E	75

Blank



APPENDIX A: **TROUBLESHOOTING**

Appendix A provides procedures for troubleshooting system hardware and software. The sections include the following topics.

- Out of the Box
- Dynamic C Will Not Start
- BL1600 Repeatedly Resets
- Dynamic C Loses Serial Link
- Common Programming Errors

Out of the Box

Check the items listed below before starting development. Rechecking may help to solve problems found during development.

- Do not connect any boards with PLCBus, RS-485 or any other I/O devices until you verify that the BL1600 runs standalone.
- Verify that the entire system has good, low-impedance, separate grounds for analog and digital signals. The BL1600 is often connected between the host PC and another device. Any differences in ground potential can cause serious problems that are hard to diagnose.
- Double-check the connecting cables. It is possible to reverse the connections to the BL1600 headers.
- Do not connect analog ground to digital ground anywhere.
- Verify that the host PC's COM port works by connecting a known-good serial device to the COM port. Remember that a PC's COM1/COM3 and COM2/COM4 share interrupts. User shells and mouse software, in particular, often interfere with proper COM-port operation. For example, a mouse running on COM1 can preclude running Dynamic C on COM3.
- Use the Z-World power supply supplied with the Developer's Kit. If another power supply must be used, verify that it has enough capacity and filtering to support the BL1600.
- Use the supplied Z-World cables. The most common fault of home-made cables is their failure to properly assert CTS at the RS-232 port of the BL1600. Without CTS being asserted, the BL1600's RS-232 port will not transmit. You can assert CTS by either connecting the RTS signal of the PC's COM port or looping back the BL1600's RTS.

Dynamic C Will Not Start

If Dynamic C will not start, an error message on the Dynamic C screen (for example, **Target Not Responding** or **Communication Error**), announces a communication failure:

- *Wrong Baud Rate* — Either Dynamic C’s baud rate is not set correctly or the BL1600’s baud rate is not set correctly. Both baud rates must be identical. The programming baud rate is set on the BL1600 by jumpering pins 1–2 or 3–4 on header J1 as described in Chapter 2. Dynamic C’s baud rate is set by the **Serial Options** command in the **OPTIONS** menu.
- *Wrong Communication Mode* — Both the PC and the BL1600 must be using RS-232. Use Dynamic C’s **Serial Options** command in the **OPTIONS** menu to check and alter the protocol for the PC.
- *Wrong COM Port* — A PC generally has two serial ports, COM1 and COM2. Specify the one used in the Dynamic C **Serial Options** command in the **OPTIONS** menu. Use trial and error, if necessary.
- *Wrong Operating Mode* — The jumpers on pins 1–2 and 3–4 of header J1 must be configured for a programming option as described in Chapter 2. Communication with Dynamic C is not possible with the BL1600 in run mode.
- *Wrong Memory Size* — Pins 5–10 on header J1 are used to specify the memory sizes of the EPROM and SRAM chips.

If all else fails, try connecting the serial cable to the BL1600 after power is applied. Some RS-232 converters enter a nondestructive latch-up, and this will overcome that problem.

BL1600 Resets Repeatedly

With the watchdog timer enabled by connecting pins 27–28 on header J1, a system reset will occur every second if the watchdog timer is not “hit” at least every 1.0 seconds. Dynamic C “hits” the timer, but a user program must include calls to `hitwd` within the application to make sure the watchdog timer is hit.

Dynamic C Loses Serial Link

If the program disables interrupts for a period greater than 50 ms, Dynamic C will lose its serial link with the program. Make sure that interrupts are not disabled for longer than 50 ms.

Common Programming Errors

- Values for constants or variables out of range. Table A-1 lists acceptable ranges for variables and constants.

Table A-1. Ranges of Dynamic C Function Types

Type	Range
int	-32,768 (-2^{15}) to +32,767 ($2^{15} - 1$)
long int	-2,147,483,648 (-2^{31}) to +2147483647 ($2^{31} - 1$)
float	1.18×10^{-38} to 3.40×10^{38}
char	0 to 255

- Mismatched “types.” For example, the literal constant **3293** is of type **int** (16-bit integer). However, the literal constant **3293.0** is of type **float**. Although Dynamic C can handle some type mismatches, avoiding type mismatches is the best practice.
- Counting up from, or down to, one instead of zero. In software, ordinal series often begin or terminate with zero, not one.
- Confusing a function’s definition with an instance of its use in a listing.
- Not ending statements with semicolons.
- Not inserting commas as required in functions’ parameter lists.
- Leaving out ASCII space character between characters forming a different legal—but unwanted—operator.
- Confusing similar-looking operators such as **&&** with **&**, **==** with **=**, and **//** with **/**.
- Inadvertently inserting ASCII nonprinting characters into a source-code file.



APPENDIX B: **SPECIFICATIONS**

Appendix B provides comprehensive BL1600 physical, electronic and environmental specifications.

Electrical and Mechanical Specifications

Table B-1 lists electrical, mechanical, and environmental specifications for the BL1600.

Table B-1. BL1600 General Specifications

Parameter	Specification
Board Size	4.52" × 4.175" × 1.0" (115 mm × 106 mm × 25 mm)
Operating Temperature	-40°C to 70°C, may be stored at -55°C to 85°C
Humidity	5% to 95%, noncondensing
Power	9 V DC to 30 V DC, 150 mA, linear supply
Digital Inputs	12, TTL and CMOS compatible, 2.5 V digital threshold (8 additional inputs possible when PLCBus is not used)
Digital Outputs	14, TTL and CMOS compatible — 7 of these are high-current outputs and can sink 100 mA each at 50°C and 48 V DC; a single channel can sink up to 500 mA continuously at 25°C
Processor	Z180
Clock	9.216 MHz
SRAM	32K standard, supports up to 512K
EPROM	32K standard, may be replaced with 128K or 256K flash EPROM
Flash EPROM	May replace factory-installed EPROM
Counters	Software-implementable
Serial Ports	Two RS-232 OR one RS-232 (with CTS/RTS) and one RS-485
Serial Rate	Up to 57,600 bps
Watchdog	Yes
Time/Date Clock	Yes
Backup Battery	Renata CR2325RH 3 V DC lithium ion, rated life 190 mA·h

BL1600 Mechanical Dimensions

Figure B-1 shows the mechanical dimensions for the BL1600.




Figure B-1. BL1600 Dimensions

Factory Default Jumper Positions

Table B-2 lists the jumper configurations for the BL1600 configurable header (J1). The header locations are shown in Figure B-2.




Figure B-2. BL1600 Headers

Table B-2. Standard BL1600 Jumper Settings on Header J1

Pin Group	Description
1-4	Operating mode: n.c. Run the program in RAM. 1-2 Place unit in programming mode at 9600 bps. 3-4 Place unit in programming mode at baud rate specified in EEPROM location 1. 1-2, 3-4 Place unit in programming mode at 19,200 bps (default)
5-10	EPROM sizes: 5-7, 6-8 32K (default) 6-8, 7-9 64K, 128K 7-9, 8-10 256K, 512K
11, 13, 15	11-13 Flash EPROM 13-15 non-flash EPROM (default)
12, 14, 16	SRAM sizing: 12-14 32K or 128K SRAM. (default) 14-16 512K SRAM
17, 19, 21	17-19 Write-protect the upper half of the EEPROM. 19-21 Write-enable the upper half of the EEPROM.
18, 20, 22, 23-26	Serial communication: 18-20 One 5-wire RS-232 channel (Z180 Port 0) with 23-25 RTS/CTS and one half-duplex RS-485 channel 24-26 (Z180 Port 1). This is the default. 20-22 Two 3-wire RS-232 channels. No RS-485. 23-24
27-28	Connect to enable the watchdog timer (default).

Table B-3 lists the header functions for the input/output and serial communication headers.

Table B-3. BL1600 Header Functions

Header	Function
H1	Digital inputs 0–11 (numbered 1–12 in the software).
H2	Digital outputs. OUTB1–OUTB8 are 8-bit parallel. OUT1–OUT6, EN485 and SCL are individually selectable.
H3	RS-232 and programming port.
H4	Miscellaneous lines. /USER1–/USER3, E, /DREQ0, /DREQ1, /INT2, /RESET.
H5	PLCBus expansion connector — this connector supports the “LCD bus” as well. Use a 26-pin ribbon cable to attach PLCBus devices to the BL1600.
J2	Screw terminal block — power, ground, RS-485, high-current outputs (HC1–HC7).

Table B-4 provides the relevant pin 1 locations for these headers.

**Table B-4. BL1600 Pin 1 Locations
(in inches from corner with heat sink)**

Header	Location
H1	0.5, 3.8
H2	1.4, 3.8
H3	2.6, 3.8
H4	0.2, 3.2
H5	0.2, 1.6

Installation Concepts

Connectors

Ideally, you should place a single, solid conductor in a screw clamp terminal. Bare copper, particularly if exposed to the air for a long period before installation, can become oxidized. The oxide can cause a high-resistance ($\sim 20 \Omega$) connection, especially if the clamping pressure is not sufficient. To avoid this, use tinned wires, clean, shiny copper wire, or crimp the connector.

If you are using multiple conductors or stranded wire, consider soldering the wire bundle or using a crimp connector to avoid a loss of contact pressure to a spontaneous rearrangement of the wire bundle at a later time. Soldering may make the wire subject to fatigue failure at the junction with the solder if there is flexing or vibration.

Power Consumption and Heat Dissipation

With the standard heat sink, the total thermal resistance at the voltage regulator is about $15.2^\circ\text{C}/\text{W}$. The smaller heat sink has a thermal resistance of about $25.2^\circ\text{C}/\text{W}$. The maximum junction temperature of the regulator is 125°C .

If the BL1600 is drawing 3 W, the regulator (with the large heat sink) will operate at

$$T_A + 3 \times 15.2^\circ\text{C} = 95.6^\circ\text{C}$$

for an ambient temperature, T_A , of 50°C . The maximum power dissipation would be

$$W_T = (125^\circ\text{C} - 50^\circ\text{C}) / (15.2^\circ\text{C}/\text{W}) = 4.93 \text{ W for the large heat sink}$$

$$W_T = (125^\circ\text{C} - 50^\circ\text{C}) / (25.2^\circ\text{C}/\text{W}) = 2.98 \text{ W for the small heat sink}$$

at 50°C . Additional power draw is possible if forced convection cooling is provided.

The BL1600 draws about 150 mA from the total current available. Therefore, the current available to external accessories or additional onboard devices is


$$I = \frac{P}{V_{IN} - 5 \text{ V}} - 150 \text{ mA} \quad . \quad (\text{B-1})$$

If the input voltage is 12 V, the total current available to accessories is 560 mA with the standard heat sink (5 W) and 270 mA with the small heat sink (3 W). For a 24 V input, the total current available is 90 mA with the standard heat sink, and no power is left over with the small heat sink. These values are approximate.

High-Voltage Drivers

Table B-5 lists the high-voltage driver characteristics when sinking drivers or sourcing drivers are used.

Table B-5. High-Voltage Driver Characteristics

Characteristic	Sinking Driver	Sourcing Driver
		
IC	ULN2003A	UDN2985A
Number of Channels	7	8
Max. Current per Channel (all channels ON)	75 mA @ 60°C 125 mA @ 50°C	75 mA @ 60°C 125 mA @ 50°C
Voltage Source Range	2 V to 48 V DC	3 V to 30 V DC
Package Power Dissipation	2.2 W @ 25°C	2.2 W @ 25°C
Max. Current (all channels ON)	1.38 A	1.38 A
Max. Collector-Emitter Voltage (VCE)	1.6 V	1.6 V
Derating	18 mW/°C (55°C/W)	18 mW/°C (55°C/W)
Output Flyback Diode (K)	Yes	Yes
Max. Diode-Drop Voltage (K)	2 V DC	2 V DC



For additional information on maximum operating conditions for the BL1600 high-voltage drivers, call Z-World Technical Support at (530) 757-3737.

Sinking Driver

The sinking-driver IC can handle a maximum of 1.38 A (500 mA for any channel), or 75 mA per channel on average if all channels are ON, at 60°C. The absolute maximum power that the driver IC can dissipate depends on several factors. The sinking IC's saturation voltage is 1.6 V DC max per channel.

The sinking driver's source voltage must range from 2 V to 48 V DC.

Sourcing Driver

The sourcing-driver IC can handle a maximum of 1.38 A (250 mA for any channel), or 75 mA per channel on average if all channels are ON, at 60°C. The sourcing IC can dissipate a maximum of 2.2 W. The saturation voltage is 1.6 V DC max per channel.



The sourcing driver's source voltage must range from 3 V to 30 V DC. The minimum output sustaining voltage is 15 V DC. Operating the driver at more than 15 V without providing for energy dissipation may destroy the driver when an inductive load is connected.



For more information on sinking and sourcing high-voltage drivers, refer to the Motorola (DL128) or Allegro (AMS 502Z) data books.



See Appendix D, "Sinking and Sourcing Drivers," for more information on installing and using sourcing drivers.



APPENDIX C:
PROTOTYPING BOARD

Introduction

The BL1600 was designed to allow customers to build expansion boards that “piggyback” on the BL1600. Z-World’s Prototyping Board lets you develop such circuitry efficiently. The Prototyping Board is an array of uncommitted pads on 0.1" centers. Five power rails bring ± 15 V, +5 V, and ground to the pads. The rails are spaced with pads judiciously connected so that you easily place and connect 300-mil and 600-mil DIPs. A large section of the board is available for discrete components.

The Prototyping Board has direct connections to the BL1600’s input/output headers: the PLCBus port, expansion header, digital inputs, digital outputs, and serial ports. The BL1600 can access up to 48 addresses on an expansion board.

Features

- **Compactness**

The Prototyping Board fits directly over the BL1600, providing a sound foundation for your design.

- **Power Rails**

There are five power rails on board allowing ICs and components easy access to various operating voltages. Each power rail supplies +15 V, -15 V, +5 V, and ground.

- **Direct Header Connections**


All the BL1600 headers connect directly the Prototyping Board.

- **Sea of Pads**

An array of pads is provided for DIPs and discrete components. Pads and power rails are arranged and interconnected so that it is easy to place and connect 300-mil and 600-mil DIPs.

- **Extra Pads**

Extra pads bring out signals from the PLCBus and the expansion header for easier soldering.



Connecting the Prototyping Board to the BL1600

Connect the Prototyping Board to the BL1600 by pressing the five header blocks underneath the Prototyping Board onto the corresponding header pins of the BL1600. The headers on the BL1600 and the Prototyping Board have the same names: H1, H2, H3, H4, and H5.

Power Supply

The power (24 V) for the Prototyping Board is obtained from pin 4 on the PLCBus (header H5). Two LM340 series regulators, shown in Figure C-2, regulate the voltage at +15 V, -15 V, and +5 V:

The output tolerance of the regulators is $\pm 2\%$ at 25°C and $\pm 4\%$ over the BL1600's operating temperature range. The complementary -15 V comes from a Harris ICL7662 voltage converter input from +15 V.







Figure C-2. BL1600 Prototyping Board Voltage Regulators





Interface with BL1600

Headers H1, H2, H3, H4 and H5 connect directly to the BL1600, bringing all relevant signals of the BL1600 to the Prototyping Board. These headers represent the PLCBus, the digital I/O, the serial channels, and the PLCBus expansion “bus.” H101, H102, H103, and H105 duplicate the digital input, output, serial, and PLCBus headers, respectively, permitting easier soldering. Header H106 duplicates the address and data lines of the PLCBus as well as its read and write signals. Header H107 duplicates the signals of H4.

The signals on these headers are listed in Table C-1.

Table C-1. BL1600 Prototyping Board Header Signals

Headers		Signals
BL1600	Prototyping Board	
H1	H101	Digital inputs IN00–IN11
H2	H102	Digital outputs OUT1–OUT6, EN485, SCL, OUTB1–OUTB8
H3	H103	RS-232, /RX0, /TX0, /RX1, /TX1
H5	H105	PLCBus (4 address lines, 8 data lines, read, write, 24 V DC, etc.)
—	H106	Address and data lines with read and write lines from the PLCBus
H4	H107	PLCBus expansion bus (/USER1–/USER3, E, /DREQ0–/DREQ1, /INT2, /RESET)



Chapter 4, “System Development,” discusses these header signals in more detail.



Z-World’s Technical Note 102, *BL1600 Prototyping Board*, describes the design an A/D converter using the Prototyping Board, and discusses the integration of the software, firmware and hardware.

Prototyping Board Pinouts

Figure C-6 shows the pinouts for the BL1600 Prototyping Board.




Figure C-6. BL1600 Prototyping Board Signals



APPENDIX D:
SINKING AND SOURCING DRIVERS

BL1600 Series Sinking and Sourcing Outputs

The BL1600 Series controllers are normally supplied with ULN2003 sinking drivers. Figure D-1 shows a typical sinking driver output configuration.




Figure D-1. BL1600 Sinking Driver Output

Sourcing outputs are possible by replacing the factory-installed sinking driver chips with sourcing output drivers (UDN2985). The UDN2985 sourcing driver chip is capable of sourcing a maximum of 75 mA per output.

Figure D-2 shows a typical sourcing driver output.




Figure D-2. BL1600 Series Sourcing Driver Output



Z-World also offers all BL1600 Series controllers for quantity orders with factory-installed sourcing drivers. For ordering information, call your Z-World Sales Representative at (530) 757-3737.

Installing Sourcing Driver

Figure D-3 shows the location of the driver to be changed.




Figure D-3. Location of BL1600 Sinking Driver

Pay particular attention to the orientation of the chip when changing the driver. Exercise caution when installing sourcing drivers in the field.

1. Be sure power is removed from the controller.
2. Remove the ULN2003 sinking driver from the IC socket.
3. Install the UDN2985 sourcing driver chip into the IC socket.

Using Output Drivers

The common supply for all seven channels supplied by a driver chip is called “K,” and is labeled as such on header J2. “K” must be powered up to allow proper operation.

The “K” connection performs two vital functions to the high-voltage driver circuitry on the BL1600.

1. “K” supplies power to driver circuitry inside the driver chip.
2. “K” also allows a diode internal to the driver chip to “snub” voltage transients produced during the inductive kick associated with switching inductive loads. (Relays, solenoids, and speakers are examples of inductive loads.)

Long leads may present enough induction to also produce large potentially damaging voltage transients. The anodes of the protection diodes for each channel are common, and so only one voltage supply can be used for all high-voltage driver loads.

The following points summarize the functions of “K.”

- K provides power to the driver chip circuitry.
- K provides “clamping” for all high-voltage driver loads.
- It is mandatory to connect K regardless of whether sourcing or sinking.
- The load’s supply must have a common ground with all other supplies in your system.
- All loads must use same supply voltage.

Refer to Figure D-4 and Figure D-5 when connecting K.




Figure D-4. BL1600 K Connections (Sinking Configuration)




Figure D-5. BL1600 K Connections (Sourcing Configuration)



K must be connected to the power supply used for the high-voltage load. See Figure D-4 and Figure D-5.



APPENDIX E: **PLCBus**

Appendix E provides the pin assignments for the PLCBus, describes the registers, and lists the software drivers.

PLCBus Overview

The PLCBus is a general-purpose expansion bus for Z-World controllers. The PLCBus is available on the BL1200, BL1600, BL1700, PK2100, and PK2200 controllers. The BL1000, BL1100, BL1300, BL1400, and BL1500 controllers support the XP8300, XP8400, XP8600, and XP8900 expansion boards using the controller's parallel input/output port. The

Two independent buses, the LCD bus and the PLCBus, exist on the single connector.

The LCD bus consists of the following lines.

- LCDX—positive-going strobe.
- /RDX—negative-going strobe for read.
- /WRX—negative-going strobe for write.
- A0X—address line for LCD register selection.
- D0X-D7X—bidirectional data lines (shared with expansion bus).

The LCD bus is used to connect Z-World's OP6000 series interfaces or to drive certain small liquid crystal displays directly. Figure E-2 illustrates the connection of an OP6000 interface to a controller PLCBus.




Figure E-2. OP6000 Connection to PLCBus Port

The PLCBus consists of the following lines.

- /STBX—negative-going strobe.
- A1X-A3X—three control lines for selecting bus operation.
- D0X-D3X—four bidirectional data lines used for 4-bit operations.
- D4X-D7X—four additional data lines for 8-bit operations.
- /AT—attention line (open drain) that may be pulled low by any device, causing an interrupt.

The PLCBus may be used as a 4-bit bus (D0X-D3X) or as an 8-bit bus (D0X-D7X). Whether it is used as a 4-bit bus or an 8-bit bus depends on the encoding of the address placed on the bus. Some PLCBus expansion cards require 4-bit addressing and others (such as the XP8700) require 8-bit addressing. These devices may be mixed on a single bus.

There are eight registers corresponding to the modes determined by bus lines A1X, A2X, and A3X. The registers are listed in Table E-2.

Table E-2. PLCBus Registers

Register	Address	A3	A2	A1	Meaning
BUSRD0	C0	0	0	0	Read data, one way
BUSRD1	C2	0	0	1	Read data, another way
BUSRD2	C4	0	1	0	Spare, or read data
BUSRESET	C6	0	1	1	Read this register to reset the PLCBus
BUSADR0	C8	1	0	0	First address nibble or byte
BUSADR1	CA	1	0	1	Second address nibble or byte
BUSADR2	CC	1	1	0	Third address nibble or byte
BUSWR	CE	1	1	1	Write data

Writing or reading one of these registers takes care of all the bus details. Functions are available in Z-World's software libraries to read from or write to expansion bus devices.

To communicate with a device on the expansion bus, first select a register associated with the device. Then read or write from/to the register. The register is selected by placing its address on the bus. Each device recognizes its own address and latches itself internally.

A typical device has three internal latches corresponding to the three address bytes. The first is latched when a matching BUSADR0 is detected. The second is latched when the first is latched and a matching BUSADR1 is detected. The third is latched if the first two are latched and a matching BUSADR2 is detected. If 4-bit addressing is used, then there are three 4-bit address nibbles, giving 12-bit addresses. In addition, a special register address is reserved for address expansion. This address, if ever used, would provide an additional four bits of addressing when using the 4-bit convention.

If eight data lines are used, then the addressing possibilities of the bus become much greater—more than 256 million addresses according to the conventions established for the bus.

Place an address on the bus by writing (bytes) to BUSADR0, BUSADR1 and BUSADR2 in succession. Since 4-bit and 8-bit addressing modes must coexist, the lower four bits of the first address byte (written to BUSADR0) identify addressing categories, and distinguish 4-bit and 8-bit modes from each other.

There are 16 address categories, as listed in Table E-3. An “x” indicates that the address bit may be a “1” or a “0.”

Table E-3. First-Level PLCBus Address Coding

First Byte	Mode	Addresses	Full Address Encoding
---- 0 0 0 0	4 bits × 3	256	0000 xxxx xxxx
---- 0 0 0 1		256	0001 xxxx xxxx
---- 0 0 1 0		256	0010 xxxx xxxx
---- 0 0 1 1		256	0011 xxxx xxxx
--- x 0 1 0 0	5 bits × 3	2,048	x0100 xxxxxx xxxxxx
--- x 0 1 0 1		2,048	x0101 xxxxxx xxxxxx
--- x 0 1 1 0		2,048	x0110 xxxxxx xxxxxx
--- x 0 1 1 1		2,048	x0111 xxxxxx xxxxxx
-- xx 1 0 0 0	6 bits × 3	16,384	xx1000 xxxxxx xxxxxx
-- xx 1 0 0 1		16,384	xx1001 xxxxxx xxxxxx
-- xx 1 0 1 0	6 bits × 1	4	xx1010
---- 1 0 1 1	4 bits × 1	1	1011 (expansion register)
xxxx 1 1 0 0	8 bits × 2	4,096	xxxx1100 xxxxxxxx
xxxx 1 1 0 1	8 bits × 3	1M	xxxx1101 xxxxxxxx xxxxxxxx
xxxx 1 1 1 0	8 bits × 1	16	xxxx1110
xxxx 1 1 1 1	8 bits × 1	16	xxxx1111

This scheme uses less than the full addressing space. The mode notation indicates how many bus address cycles must take place and how many bits are placed on the bus during each cycle. For example, the 5 × 3 mode means three bus cycles with five address bits each time to yield 15-bit addresses, not 24-bit addresses, since the bus uses only the lower five bits of the three address bytes.

Z-World provides software drivers that access the PLCBus. To allow access to bus devices in a multiprocessing environment, the expansion register and the address registers are shadowed with memory locations known as *shadow registers*. The 4-byte shadow registers, which are saved at predefined memory addresses, are as follows.

SHBUS0	SHBUS0+1	SHBUS1 SHBUS0+2	SHBUS1+1 SHBUS0+3
Bus expansion	BUSADR0	BUSADR1	BUSADR2

Before the new addresses or expansion register values are output to the bus, their values are stored in the shadow registers. All interrupts that use the bus save the four shadow registers on the stack. Then, when exiting the interrupt routine, they restore the shadow registers and output the three address registers and the expansion registers to the bus. This allows an interrupt routine to access the bus without disturbing the activity of a background routine that also accesses the bus.

To work reliably, bus devices must be designed according to the following rules.

1. The device must not rely on critical timing such as a minimum delay between two successive register accesses.
2. The device must be capable of being selected and deselected without adversely affecting the internal operation of the controller.

Allocation of Devices on the Bus

4-Bit Devices

Table E-4 provides the address allocations for the registers of 4-bit devices.

Table E-4. Allocation of Registers

A1	A2	A3	Meaning
000j	000j	xxxj	digital output registers, 64 registers $64 \times 8 = 512$ 1-bit registers
000j	001j	xxxj	analog output modules, 64 registers
000j	01xj	xxxj	digital input registers, 128 registers $128 \times 4 = 512$ input bits
000j	10xj	xxxj	analog input modules, 128 registers
000j	11xj	xxxj	128 spare registers (customer)
001j	xxxj	xxxj	512 spare registers (Z-World)

j controlled by board jumper
x controlled by PAL

Digital output devices, such as relay drivers, should be addressed with three 4-bit addresses followed by a 4-bit data write to the control register. The control registers are configured as follows

bit 3	bit 2	bit 1	bit 0
A2	A1	A0	D

The three address lines determine which output bit is to be written. The output is set as either 1 or 0, according to D. If the device exists on the bus, reading the register drives bit 0 low. Otherwise bit 0 is a 1.

For digital input, each register (BUSRD0) returns four bits. The read register, BUSRD1, drives bit 0 low if the device exists on the bus.

8-Bit Devices

Z-World's XP8700 and XP8800 expansion boards use 8-bit addressing. Refer to the *XP8700 and XP8800* manual.

Expansion Bus Software

The expansion bus provides a convenient way to interface Z-World's controllers with expansion boards or other specially designed boards. The expansion bus may be accessed by using input functions. Follow the suggested protocol. The software drivers are easier to use, but are less efficient in some cases. Table E-5 lists the libraries.

Table E-5. Dynamic C PLCBus Libraries

Library Needed	Controller
DRIVERS.LIB	All controllers
EZIOTGPL.LIB	BL1000
EZIOLGPL.LIB	BL1100
EZIOMGPL.LIB	BL1400, BL1500
EZIOPLC.LIB	BL1200, BL1600, PK2100, PK2200, ZB4100
EZIOPLC2.LIB	BL1700
EZIOBL17.LIB	BL1700
PBUS_TG.LIB	BL1000
PBUS_LG.LIB	BL1100, BL1300
PLC_EXP.LIB	BL1200, BL1600, PK2100, PK2200

There are 4-bit and 8-bit drivers. The 4-bit drivers employ the following calls.

- **void eioResetPlcBus ()**

Resets all expansion boards on the PLCBus. When using this call, make sure there is sufficient delay between this call and the first access to an expansion board.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB.**

- **void eioPlcAdr12(unsigned addr)**

Specifies the address to be written to the PLCBus using cycles BUSADR0, BUSADR1, and BUSADR2.

PARAMETER: **addr** is broken into three nibbles, and one nibble is written in each BUSADR_x cycle.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB.**

- **void set16adr(int adr)**

Sets the current address for the PLCBus. All read and write operations access this address until a new address is set.

PARAMETER: **adr** is a 16-bit physical address. The high-order nibble contains the value for the expansion register, and the remaining three 4-bit nibbles form a 12-bit address (the first and last nibbles must be swapped).

LIBRARY: **DRIVERS.LIB.**

- **void set12adr(int adr)**

Sets the current address for the PLCBus. All read and write operations access this address until a new address is set.

PARAMETER: **adr** is a 12-bit physical address (three 4-bit nibbles) with the first and third nibbles swapped.

LIBRARY: **DRIVERS.LIB.**

- **void eioPlcAdr4(unsigned addr)**

Specifies the address to be written to the PLCBus using only cycle BUSADR2.

PARAMETER: **addr** is the nibble corresponding to BUSADR2.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB.**

- **void set4adr(int adr)**

Sets the current address for the PLCBus. All read and write operations access this address until a new address is set.

A 12-bit address may be passed to this function, but only the last four bits will be set. Call this function only if the first eight bits of the address are the same as the address in the previous call to **set12adr**.

PARAMETER: **adr** contains the last four bits (bits 8–11) of the physical address.

LIBRARY: **DRIVERS.LIB**.

- **char _eioReadD0()**

Reads the data on the PLCBus in the BUSADR0 cycle.

RETURN VALUE: the byte read on the PLCBus in the BUSADR0 cycle.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB**.

- **char _eioReadD1()**

Reads the data on the PLCBus in the BUSADR1 cycle.

RETURN VALUE: the byte read on the PLCBus in the BUSADR1 cycle.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB**.

- **char _eioReadD2()**

Reads the data on the PLCBus in the BUSADR2 cycle.

RETURN VALUE: the byte read on the PLCBus in the BUSADR2 cycle.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB**.

- **char read12data(int adr)**

Sets the current PLCBus address using the 12-bit **adr**, then reads four bits of data from the PLCBus with BUSADR0 cycle.

RETURN VALUE: PLCBus data in the lower four bits; the upper bits are undefined.

LIBRARY: **DRIVERS.LIB**.

- **char read4data(int adr)**

Sets the last four bits of the current PLCBus address using `adr` bits 8–11, then reads four bits of data from the bus with `BUSADR0` cycle.

PARAMETER: `adr` bits 8–11 specifies the address to read.

RETURN VALUE: PLCBus data in the lower four bits; the upper bits are undefined.

LIBRARY: **DRIVERS.LIB.**

- **void _eioWriteWR(char ch)**

Writes information to the PLCBus during the `BUSWR` cycle.

PARAMETER: `ch` is the character to be written to the PLCBus.

LIBRARY: **EZIOPLC.LIB, EZIOPLC2.LIB, EZIOMGPL.LIB.**

- **void write12data(int adr, char dat)**

Sets the current PLCBus address, then writes four bits of data to the PLCBus.

PARAMETER: `adr` is the 12-bit address to which the PLCBus is set.

`dat` (bits 0–3) specifies the data to write to the PLCBus.

LIBRARY: **DRIVERS.LIB.**

- **void write4data(int address, char data)**

Sets the last four bits of the current PLCBus address, then writes four bits of data to the PLCBus.

PARAMETER: `adr` contains the last four bits of the physical address (bits 8–11).

`dat` (bits 0–3) specifies the data to write to the PLCBus.

LIBRARY: **DRIVERS.LIB.**

The 8-bit drivers employ the following calls.

- **void set24adr(long address)**

Sets a 24-bit address (three 8-bit nibbles) on the PLCBus. All read and write operations will access this address until a new address is set.

PARAMETER: `address` is a 24-bit physical address (for 8-bit bus) with the first and third bytes swapped (low byte most significant).

LIBRARY: **DRIVERS.LIB.**

- **void set8adr(long address)**

Sets the current address on the PLCBus. All read and write operations will access this address until a new address is set.

PARAMETER: **address** contains the last eight bits of the physical address in bits 16–23. A 24-bit address may be passed to this function, but only the last eight bits will be set. Call this function only if the first 16 bits of the address are the same as the address in the previous call to **set24adr**.

LIBRARY: **DRIVERS.LIB**.

- **int read24data0(long address)**

Sets the current PLCBus address using the 24-bit address, then reads eight bits of data from the PLCBus with a BUSRD0 cycle.

RETURN VALUE: PLCBus data in lower eight bits (upper bits 0).

LIBRARY: **DRIVERS.LIB**.

- **int read8data0(long address)**

Sets the last eight bits of the current PLCBus address using address bits 16–23, then reads eight bits of data from the PLCBus with a BUSRD0 cycle.

PARAMETER: **address** bits 16–23 are read.

RETURN VALUE: PLCBus data in lower eight bits (upper bits 0).

LIBRARY: **DRIVERS.LIB**.

- **void write24data(long address, char data)**

Sets the current PLCBus address using the 24-bit address, then writes eight bits of data to the PLCBus.

PARAMETERS: **address** is 24-bit address to write to.

data is data to write to the PLCBus.

LIBRARY: **DRIVERS.LIB**.

- **void write8data(long address, char data)**

Sets the last eight bits of the current PLCBus address using address bits 16–23, then writes eight bits of data to the PLCBus.

PARAMETERS: **address** bits 16–23 are the address of the PLCBus to write.

data is data to write to the PLCBus.

LIBRARY: **DRIVERS.LIB**.

Blank



APPENDIX F:
EEPROM

EEPROM Parameters

The onboard EEPROM (electrically erasable, programmable, read-only memory) is used to store the constants and parameters listed in Table F-1. The five bytes presently in use determine the operation of the BL1600 board when it starts up.

Table F-1. BL1600 EEPROM Assignments

Address	Definition
0	Startup Mode — if 1, enter program mode; if 8, execute loaded program at startup.
1	Programming baud rate in multiples of 1200 bps. The factory default is 48, meaning 57,600 bps. This location applies only if J1 pins 1–2 are <i>not</i> connected and J1 pins 3–4 <i>are</i> connected.
0x100	Unit “serial number” in BCD time and date with the following format: second, minutes, hours, day, month, and year.
0x108	Microprocessor clock speed in multiples of 1200 Hz (16 bits). (This value is 7680 for a 9.216 MHz clock speed.)
0x16C	Long coefficient relating speed of microprocessor clock relative to speed of real-time clock. Nominal value is 107,374,182, which is 1/40 of a second microprocessor clock time on the scale where 2^{32} is 1 second. This requires 4 bytes of EEPROM, stored least byte first.

The EEPROM has 512 bytes. The upper 256 bytes can be written to only when pins 19 and 21 on header J1 are connected. Connect pins 17 and 19 on header J1 to write-protect the EEPROM.

Baud Rate

When the EEPROM is first initialized, the baud rate is set to 57,600 bps. The next section outlines the procedure to change these parameters.

Startup Mode

In *programming* mode, the board initializes Serial Port 0 for Dynamic C. When set for *run* mode, the board attempts to execute a user-written program stored in battery-backed RAM or in EPROM.

The baud rate code determines the serial communication rate at which the BL1600 attempts to communicate with the PC and Dynamic C.

Clock Speed

The clock speed code is used by the BL1600 to compute parameters necessary to set the serial port. The clock speed is also used by several Dynamic C library functions.

Changing Parameters Stored in EEPROM

- 1 Install jumper across pins 19–21 on header J1.
- 2 Use the `ee_wr` function to change the parameters.
- 3 Reset the BL1600 by interrupting power or by momentarily connecting pins 9–10 on header H4.
- 4 Reconnect pins 17–19 on header J1. The BL1600 will automatically use the new mode or baud rate specified for the next restart. The board will continue to operate with the new setting until the EEPROM is changed.

Follow the above procedures to change any of the parameters listed in Table F-1. First, perform the procedure for one of these parameters, then repeat the procedure for the other parameters.

Library Routines

The following library routines can be used to read and write the EEPROM.

```
int ee_rd( int address );  
int ee_wr( int address, char value );
```

The function `ee_rd` returns the data value in the lower byte, and the function `ee_wr` writes the character value at address. The functions return a negative value if there is a hardware problem. If this happens with `ee_wr`, try writing again after checking pins 19–21 on header J1 to make sure the EEPROM is write-enabled. Repeated negative values may be indicative of a worn-out EEPROM. A write-protection violation does not wear out the EEPROM.

These routines each require about 2.5 ms to execute. They are not re-entrant, that is, only one routine at a time will run.



The EEPROM has a rated lifetime of only 10,000 writes (unlimited reads). Do not write the EEPROM from within a loop. The EEPROM should be written to only in response to a human request for each write.

Blank



APPENDIX G: MEMORY, I/O MAP, AND INTERRUPT VECTORS

Appendix G provides detailed information on memory, provides an I/O map, and lists the interrupt vectors.

BL1600 Memory

Figure G-1 shows Tm4 memory map of Tm4 1M address space.




Figure G-1. Memory Map of Tm4 1M Address Space

Figure G-2 shows Tm4 memory map within Tm4 64K virtual space.




Figure G-2. Memory Map of Tm4 64K Virtual Space

Tm4 various registers in Tm4 input/output (I/O) space can be accessed in Dynamic C by Tm4 symbolic names listed below. Tm4se names are treated as unsigned integer constants. Tm4 Dynamic C library functions `inport` and `outport` access Tm4 I/O registers directly.


```
data_value = inport( CNTLA0 );
outport( CNTLA0, data_value );
```


Memory and Input/Output Cycle Timing

There are two types of memory cycles that need to be considered: standard memory cycles and Load Instruction Register (LIR) cycles. LIR cycles, which fetch the op code, have the most critical timing requirement. The memory access time, t , in nanoseconds, can be calculated for these cycles using

$$t = 2T - 95 \text{ ,} \quad (\text{G-1})$$

where T is the period of a clock cycle. Figure G-3 shows these cycles with and without a wait state.



0 wait access time = $2T - 95$ ns = 122 ns for 9.216 MHz clock	1 wait access time = $3T - 95$ ns = 230 ns for 9.216 MHz clock
---	---

Figure G-3. Memory Cycles for 9.216 MHz Processor With and Without a Wait State

The standard version of the PAL generates a wait state only during the LIR cycles. Therefore it is called a “½ wait state” PAL.

The standard memory cycles require an access time of $2.5T - 95$ nanoseconds. Table G-1 lists the memory access times required for various clock frequencies and wait states.

Table G-1. Memory Access Times (ns)

Clock Frequency	EPROM	SRAM
9.216 MHz, 0 wait states	122	176
9.216 MHz, 1 wait state	230	283

The memory access times in Table G-1 were calculated assuming that LIR cycles only take place in EPROM. These access times are conservative, and no problem should be encountered by using an EPROM with a memory access time that is more than the time listed in Table G-1.

Input/Output Cycle Timing

Customer peripheral devices are usually interfaced as I/O devices. This is convenient because only eight address lines need to be decoded in most cases. Figure G-4 shows how wait cycles are inserted in I/O cycles. At least one wait cycle (T_w) is always inserted. Up to four additional wait states can be inserted, depending on the setup of the wait-state generator. One additional wait state, the default number (T_{w1}), is shown in Figure G-4.




Figure G-4. Inserting Wait Cycles in I/O Cycles

Execution Timing

The times reported in Table G-2 were measured using Dynamic C and they reflect the use of Dynamic C libraries. The time required to fetch the arguments from memory, but not to store the result, is included in the timings. The times are for a 9.216 MHz clock with 0 wait states.

Table G-2. BL1600 Execution Times for Dynamic C

Operation	Execution Time (μs)
DMA copy (per byte)	0.73
Integer assignment (i=j;)	3.4
Integer add (j+k;)	4.4
Integer multiply (j*k;)	18
Integer divide (j/k;)	90
Floating add (p+q;) (typical)	85
Floating multiply (p*q;)	113
Floating divide (p/q;)	320
Long add (l+m;)	28
Long multiply (l*m;)	97
Long divide (l/m;)	415
Floating square root (sqrt(q);)	849
Floating exponent (exp(q);)	2503
Floating cosine (cos(q);)	3049

The execution times can be adjusted proportionally for clock speeds other than 9.216 MHz. Operations involving one wait state will slow the execution speed about 25%.

Memory Map

Input/Output Select Map

The Dynamic C library functions **IBIT**, **ISET** and **IRES** in the **BIOS.LIB** library allow bits in the I/O registers to be tested, set, and cleared. Both 16-bit and 8-bit I/O addresses can be used.

Z180 Internal Input/Output Registers Addresses 0x00–0x3F

The internal registers for the I/O devices built into to the Z180 processor occupy the first 40 (hex) addresses of the I/O space. These addresses are listed in Table G-3.

Table G-3. Z180 Internal I/O Registers Addresses 0x00–0x3F

Address	Name	Description
0x00	CNTLA0	Serial Channel 0, Control Register A
0x 01	CNTLA1	Serial Channel 1, Control Register A
0x02	CNTLB0	Serial Channel 0, Control Register B
0x03	CNTLB1	Serial Channel 1, Control Register B
0x04	STAT0	Serial Channel 0, Status Register
0x05	STAT1	Serial Channel 1, Status Register
0x06	TDR0	Serial Channel 0, Transmit Data Register
0x07	TDR1	Serial Channel 1, Transmit Data Register
0x08	RDR0	Serial Channel 0, Receive Data Register
0x09	RDR1	Serial Channel 1, Receive Data Register
0x0A	CNTR	Clocked Serial Control Register
0x0B	TRDR	Clocked Serial Data Register
0x0C	TMDR0L	Timer Data Register Channel 0, least
0x0D	TMDR0H	Timer Data Register Channel 0, most
0x0E	RLDR0L	Timer Reload Register Channel 0, least
0x0F	RLDR0H	Timer Reload Register Channel 0, most
0x10	TCR	Timer Control Register
0x11–0x13	—	Reserved
0x14	TMDR1L	Timer Data Register Channel 1, least
0x15	TMDR1H	Timer Data Register Channel 1, most
0x16	RLDR1L	Timer Reload Register Channel 1, least
0x17	RLDR1H	Timer Reload Register Channel 1, most

continued...

Table G-3. Z180 Internal I/O Registers Addresses 0x00–0x3F (concluded)

Address	Name	Description
0x18	FRC	Free-running counter
0x19–0x1F	—	Reserved
0x20	SAR0L	DMA source address Channel 0, least
0x21	SAR0H	DMA source address Channel 0, most
0x22	SAR0B	DMA source address Channel 0, extra bits
0x23	DAR0L	DMA destination address Channel 0, least
0x24	DAR0H	DMA destination address Channel 0, most
0x25	DAR0B	DMA destination address Channel 0, extra bits
0x26	BCR0L	DMA Byte Count Register Channel 0, least
0x27	BCR0H	DMA Byte Count Register Channel 0, most
0x28	MAR1L	DMA Memory Address Register Channel 1, least
0x29	MAR1H	DMA Memory Address Register Channel 1, most
0x2A	MAR1B	DMA Memory Address Register Channel 1, extra bits
0x2B	IAR1L	DMA I/O Address Register Channel 1, least
0x2C	IAR1H	DMA I/O Address Register Channel 1, most
0x2D	—	Reserved
0x2E	BCR1L	DMA Byte Count Register Channel 1, least
0x2F	BCR1H	DMA Byte Count Register Channel 1, most
0x30	DSTAT	DMA Status Register
0x31	DMODE	DMA Mode Register
0x32	DCNTL	DMA/WAIT Control Register
0x33	IL	Interrupt Vector Low Register
0x34	ITC	Interrupt/Trap Control Register
0x35	—	Reserved
0x36	RCR	Refresh Control Register
0x37	—	Reserved
0x38	CBR	MMU Common Base Register
0x39	BBR	MMU Bank Base Register
0x3A	CBAR	MMU Common/ Bank Area Register
0x3B–0x3D	—	Reserved
0x3E	OMCR	Operation Mode Control Register
0x3F	ICR	I/O Control Register

Epson 72421 Timer Registers 0x4000–0x400F

Table G-4 lists the Epson 72421 timer registers.

Table G-4. Epson 72421 Timer Registers 0x4000–0x400F

Address	Name	Data Bits	Description
0x4000	SEC1	D7–D0	seconds
0x4001		D7–D0	10 seconds
0x4002		D7–D0	minutes
0x103		D7–D0	10 minutes
0x4004		D7–D0	hours
0x4005		D7–D0	10 hours
0x4006		D7–D0	days
0x4007		D7–D0	10 days
0x4008		D7–D0	months
0x4009		D7–D0	10 months
0x400A		D7–D0	years
0x400B		D7–D0	10 years
0x400C		D7–D0	day of week
0x400D	TREGD	D7–D0	Register D
0x400E		D7–D0	Register E
0x400F		D7–D0	Register F

Other Addresses

Table G-5 lists the other registers.

Table G-5. Other I/O Addresses

Address	Name	Data Bits	Description
0x040	SDA_W	D7	EEPROM serial data, write. Bit 7.
0x080	LCDRD LCDWR	D0–D7	LCD read/write register, control.
0x081	LCDRD+1 LCDWR+1	D0–D7	LCD read/write register, data.
0x110	INENLO	D0–D7	Bits 0–7 represent digital inputs 0–7.
0x111	INENHI	D0–D3	Bits 0–3 represent digital inputs 8–11.
0x111	CONFIG	D4	Bit 4 represents pins 1-2 on header J1.
0x111	SDA_R	D5	Read bit 5 to get EEPROM SDA line.
0x111	NMI	D6	Bit 6 is the power-failure (NMI) state.
0x111	CONFIG	D7	Bit 7 represents pins 3-4 on header J1.
0x120	DRV1	D0	High-current output 1 (HC1). Bit 0. This output also appears on H2.
0x121	DRV2	D0	High-current output 2 (HC2). Bit 0. This output also appears on H2.
0x122	DRV3	D0	High-current output 3 (HC3). Bit 0. This output also appears on H2.
0x123	DRV4	D0	High-current output 4 (HC4). Bit 0. This output also appears on H2.
0x124	DRV5	D0	High-current output 5 (HC5). Bit 0. This output also appears on H2.
0x125	DRV6	D0	High-current output 6 (HC6). Bit 0. This output also appears on H2.
0x126	ENB485	D0	Set bit 0 to enable RS-485 transmission. Clear bit 0 to disable. The line controlled by this bit can also be used as a digital output channel and a high-current channel (HC7).

continued...

Table G-5. Other I/O Addresses (concluded)

Address	Name	Data Bits	Description
0x127	SCL	D0	EEPROM clock bit. Set the clock high by setting bit 0 of this address, and low by clearing bit 0.
0x130	OUTBYTE	D0–D7	8-bit parallel TTL-level digital output (OUTB1–OUTB8 on the schematic).
0x150	USER1	—	Base address of expansion register group 1. These 16 registers have addresses 0x150 to 0x15F. Addressing any of these registers makes /USER1 assert.
0x160	USER2	—	Base address of expansion register group 2. These 16 registers have addresses 0x160 to 0x16F. Addressing any of these registers makes /USER2 assert.
0x170	USER3	—	Base address of expansion register group 3. These 16 registers have addresses 0x170 to 0x17F. Addressing any of these registers makes /USER3 assert.
0x1C0	WDOG	—	Watchdog is “hit” (J1:27-28 enables watchdog) by reading or writing this address.

Interrupt Vectors

Table G-6 presents a suggested interrupt vector map. Most of these interrupt vectors can be altered under program control. The addresses are given here in hex, relative to the start of the interrupt vector page, as determined by the contents of the I-register. These are the default interrupt vectors set by the boot code in the Dynamic C EPROM.

Table G-6. Interrupt Vectors for Z180 Internal Devices

Address	Name	Description
0x00	INT1_VEC	Expansion bus attention INT1 vector.
0x02	INT2_VEC	INT2 vector, can be jumpered to the output of the real-time clock for a periodic interrupt
0x04	PRT0_VEC	PRT Timer Channel 0
0x06	PRT1_VEC	PRT Timer Channel 1
0x08	DMA0_VEC	DMA Channel 0
0x0A	DMA1_VEC	DMA Channel 1
0x0C	CSIO_VEC	Clocked Serial I/O
0x0E	SER0_VEC	Asynchronous Serial Port Channel 0
0x10	SER1_VEC	Asynchronous Serial Port Channel 1

To “vector” an interrupt to a user function in Dynamic C, use a directive such as the following.

```
#INT_VEC 0x10 myfunction
```

The above example causes the interrupt at offset 10H (Serial Port 1 of the Z180) to invoke the function `myfunction()`. The function must be declared with the `interrupt` keyword, as shown below.

```
interrupt myfunction() {  
    ...  
}
```



Refer to the Dynamic C manuals for further details on interrupt functions.

Nonmaskable Interrupts

Power Failure Interrupts

The following sequence of events takes place when power fails.

1. The power-failure nonmaskable interrupt (NMI) is triggered when the unregulated DC input voltage falls below approximately 7.9 V.
2. The system reset is triggered when the regulated +5 V supply falls below 4.65 V. The reset remains enabled as the voltage falls further. At this point, the chip select for the SRAM is forced high (standby mode).
3. The time/date clock and SRAM are switched to the lithium backup battery as the regulated voltage falls below the battery voltage of approximately 3 V.

The following function shows how to handle a power-failure interrupt.

```
#JUMP_VEC NMI_VEC myint
interrupt retn myint(){
    body of interrupt routine
    while(!IBIT(WDO,0)) {}
    // input voltage is still below the threshold
    // that triggered the NMI
    return; // if just a power glitch, return
}
```

Normally, a power-failure interrupt routine will not return, but will execute the shutdown code and then enter a loop until the +5 V voltage falls low enough to trigger a reset. However, the voltage might fall low enough in a “brownout” situation to trigger a power failure interrupt, but not low enough to reset, resulting in an endless hangup. Bit 0 of WDO is 0 when the voltage level is below the NMI threshold, and 1 otherwise. If this bit indicates that the low-voltage condition has reversed itself, then the power-fail routine can restart execution. If a low—but not fatally low—voltage persists, then you will have to decide what action to take, if any.

A situation similar to a brownout will occur if the power supply is overloaded. For example, when an LED is turned on, the voltage supplied to the Z180 may dip below 7.9 V. The interrupt routine does a shutdown. This turns the LED off, clearing the problem. However, the cause of the overload may persist, and the system will oscillate, alternately experiencing an overload and then resetting. To correct this situation, you need to get a larger power supply.

Do not forget the interaction between the watchdog timer and the power-failure interrupt. If a brownout causes an extended stay in the power-failure interrupt routine, the watchdog can time out and cause a system restart.

A few milliseconds of computing time remain when the +5 V supply falls below 4.5 V, even if power is abruptly cut off from the board. The amount of time depends on the size of the capacitors in the power supply. The standard wall transformer provides about 10 ms. If the power cable is abruptly removed from the BL1600 side, only the capacitors on the board are available and the computing time is reduced to a few hundred microseconds. These times can vary considerably depending on the system configuration and loads on the 5 V or 9 V power supplies.

The interval between the power-failure detection and entry to the power-failure interrupt routine is approximately 100 μ s, or less if Dynamic C NMI communications is not in use.

Testing power-failure interrupt routines presents some problems. Normally, a power-failure interrupt routine disables interrupts. Probably the best test method is to leave messages in battery-backed memory to track the execution of the power-failure routines. Use a variable transformer to simulate brownouts and other types of power-failure conditions.

The power-failure interrupt must be disabled if an external +5 V power supply is used.

Jump Vectors

These special interrupts occur in a different manner. Instead of loading the address of the interrupt routine from the interrupt vector, these interrupts cause a jump directly to the address of the vector, which will contain a jump instruction to the interrupt routine. This example illustrates a jump vector.

```
0x66    nonmaskable power-failure interrupt
```

Since nonmaskable interrupts (NMI) can be used for Dynamic C communications, an interrupt vector for power failure is normally stored just in front of the Dynamic C program. Use the command

```
#JUMP_VEC NMI_VEC name
```

to store the vector here.

The Dynamic C communication routines relay to this vector when the NMI is caused by a power failure rather than by a serial interrupt.

Interrupt Priorities

Table G-7 lists the interrupt priorities.

Table G-7. Interrupt Priorities

Interrupt Priorities	
(Highest Priority)	Trap (illegal instruction)
	NMI (nonmaskable interrupt)
	INT 0 (maskable interrupts, Level 0; three modes)
	INT 1 (maskable interrupts, Level 1; PLCBus attention line interrupt)
	INT 2 (maskable interrupts, Level 2)
	PRT Timer Channel 0
	PRT Timer Channel 1
	DMA Channel 0
	DMA Channel 1
	Clocked Serial I/O
	Z180 Serial Port 0
(Lowest Priority)	Z180 Serial Port 1



APPENDIX H: **POWER MANAGEMENT**

Appendix H provides information about power management and handling power failures.

ADM691 Power Supervisor

The ADM691 power-supervisor IC (U13) helps the system survive power fluctuations and outages. It provides these vital services.

- **Power-on reset.**

The ADM691 generates the power-on reset for the BL1600 by holding **/RESET** low until the IC's internal comparators sense that VCC has risen above 4.65 V (the IC's preset reset threshold).

- **RAM protection**

The ADM691 gates the decoded RAM-select line, **/RAMCEIN**, to the RAM's chip-enable line, **/RAMCE**, whenever VCC is above the reset threshold and VBAT. When VCC falls below the threshold, the ADM691 deasserts **/RAMCE** to prevent spurious writing to the RAM.

- **Watchdog timer**

The ADM691 provides a watchdog timer that guards against system or software faults by resetting the BL1600 if the software does not “hit” the watchdog timer input, **WDI**, at least every 1.0 seconds. Hit the watchdog timer by calling the function `hitwd`.

The supervisor's watchdog output, **WDO**, connects to the Z180's RXS/CTSI- interrupt line; **WDO** is at a logic zero level after a watchdog reset and a logic 1 after a power-on reset.

- **Nonmaskable interrupt**

The ADM691 generates a nonmaskable interrupt, **/NMI**, from its power-fail output, **/PFO**, if the unregulated DC input, normally 9 V to 12 V DC, falls below 7.9 V, giving the BL1600 advanced warning of an impending power failure so that it can execute shutdown routines. The voltage divider, R1-R2, determines this 7.9 V level.

/NMI also connects to the Z180 via multiplexer U2 to allow your software to monitor the **/NMI** line after the nonmaskable interrupt, and to recover from temporary low-input voltage conditions or “brown-outs.”

- **Backup-battery switchover**

The ADM691 switches the RAM over to battery power if VCC falls below the battery's voltage

Power Failure Management

Figure H-1 shows the power-failure detection circuitry of the BL1600.




Figure H-1. BL1600 Power-Failure Detection Circuit

Power Failure Sequence

The following events occur as the input power fails.

1. The ADM691 first triggers a power-failure **/NMI** (nonmaskable interrupt) when the unregulated DC input voltage falls below approximately 7.9 V (as determined by the voltage divider R1–R2), allowing the power-failure routine to store important state data during the “holdup” interval, t_{H1} .
2. At some point, the raw input voltage level will drop below the regulated voltage level required by the regulator’s dropout voltage, whereupon the regulated output will begin to droop. The ADM691 next triggers a system reset, **/RESET**, when the regulated +5 V supply falls below ≈ 4.65 V. The ADM691 forces the chip-enable line of the SRAM high (standby mode). Thus your power-failure routine uses the “holdup” interval (the time between steps 1 and 2), t_{H1} , to store important state data.
3. The SRAM switches to the backup battery when the regulated voltage falls below the battery’s voltage, preserving the RAM’s data.
4. The ADM691 keeps **/RESET** enabled until the regulated voltage drops below 1 V. At this point the ADM691 ceases operating. By this time, the portion of the circuitry not battery-backed should have long since ceased functioning.

Figure H-2 shows the power-failure sequence.




Figure H-2. Power-Failure Sequence

Of course, if the DC input voltage continues to decrease, then the controller will just power down. The routine calls `hitwd` to make sure that the watchdog does not time out and thereby reset the processor. The controller can continue to run, after a fashion, at low voltages, and might not be able to detect the low-voltage condition because the Z180's `/NMI` input needs to see a high-to-low transition edge.

A situation similar to a brownout will occur if the power supply is overloaded. In such a case, when a high-current load turns on, the raw voltage supplied to the Z180 may dip below 7.9 V. In response, the interrupt routine does a shutdown. This shutdown turns off the high-current load, clearing the problem. However, if the cause of the overload persists, the system will “hunt,” alternately experiencing an overload and then resetting. To correct this situation, you must get a larger power supply.

Holdup Time

A few milliseconds of computing time remain until the regulated +5 V supply falls below ~4.65 V, even if the power cuts off abruptly. The amount of time depends on the size of the capacitors in the power supply. The standard power supply included with Z-World's Developer's Kit provides about 10 ms. If the power cable is removed abruptly from the BL1600 side, then only the capacitors on the board are available, reducing computing time to a few hundred microseconds. These times can vary considerably depending on the system's configuration and loads on the 5 V or 9 V supplies.

The interval between detection of the power failure detection and entry to the power-failure interrupt routine is approximately 6 μ s or less

Z-World cannot predict how much time will actually be available to save important state data. The ratio of the raw DC power supply's output capacitor's value to the circuit's current draw determines the actual duration of the holdup time, t_H .

Multiple Power-Line Insults

This simple setup can fail when multiple power fluctuations follow each other rapidly—a common occurrence. If the BL1600's Z180 microprocessor receives multiple **/NMI**s, it will overwrite an internal register, making a correct return from the first **/NMI** impossible. Also, depending on the number of fluctuations of the raw DC input (and hence, the number of stacked **/NMI**s), the microprocessor's stack could possibly overflow, corrupting the program's code or data.

When the Z180 senses an **/NMI**, it saves the program counter (PC) on its processor stack. The Z180 copies the maskable interrupt flag, IEF1, to IEF2 and zeroes IEF1. The Z180 will restore IEF2's saved state information when it executes a RETN (return from nonmaskable interrupt) instruction.

Sample Program to Handle Power Failure

Z-World recommends the following routine to handle an **/NMI**. The routines monitor the state of the **/PFO** line via U2 and the data bus to determine if the brownout condition is continuing or if the power has returned to normal levels. If you use this routine, you will never have to worry about multiple power-failure **/NMIs** because this routine simply never returns from the first **/NMI** unless the power returns.

```
main() {
    ...
}
...
char dummy[24];      // reserve dummy stack
                    // for /NMI processing
...
#define NMI_BIT 6    // routine will test data
                    // bit 6 to determine
                    // state of /NMI line

#JUMP_VEC NMI_VEC myint
#asm
myint::
    ld    sp,dummy+24 ; force stack pointer
                    ; to top of "dummy"
                    ; array to prevent
                    ; overwriting of code
                    ; or data

        do whatever service, within allowable execution time

loop:
    call hitwd      ; make sure no
                    ; watchdog reset
                    ; during brownout

    ld    bc,NMI    ; load the read-NMI
                    ; register to bc

    in    a,(c)     ; read the read-NMI
                    ; register to /PFO

    bit   NMI_BIT, a ; check /PFO status
    jr   z,loop     ; wait until brownout
                    ; condition clears

timeout:
                    ; then... a tight loop
                    ; to force a watchdog
                    ; timeout

    jp   timeout    ; which will reset the
                    ; Z180

#endasm
```



APPENDIX I: **BATTERY**

Appendix I provides information about the onboard lithium backup battery.

Battery Life and Storage Conditions

The battery on the BL1600 controller will provide at least 9,000 hours of backup time for the onboard real-time clock and SRAM. However, backup time longevity is affected by many factors, including the amount of time the controller is unpowered and the SRAM size. Most systems are operated on a continuous basis, with the battery supplying power to the real-time clock and the SRAM during power outages and/or during routine maintenance. The time estimate reflects the shelf life of a lithium ion battery with occasional use rather than the ability of the battery to power the circuitry full time.

The battery has a capacity of 190 mA·h. At 25°C, the real-time clock draws 3 μ A when idle, and the 32K SRAM draws 2 μ A. If the BL1600 were unpowered 100 percent of the time, the battery would last 38,000 hours (4.3 years).

To maximize the battery life, the BL1600 should be stored at room temperature in the factory packaging until field installation. Take care that the BL1600 is not exposed to extreme temperature, humidity, and/or contaminants such as dust and chemicals.

To ensure maximum battery shelf life, follow proper storage procedures. Replacement batteries should be kept sealed in the factory packaging at room temperature until installation. Protection against environmental extremes will help maximize battery life.

Replacing Soldered Lithium Battery

Use the following steps to replace the battery.

1. Locate the three pins on the bottom side of the printed circuit board that secure the battery to the board.
2. Carefully de-solder the pins and remove the battery. Use a solder sucker to clean up the holes.
3. Install the new battery and solder it to the board. Use only a Renata CR2325RH or its equivalent.

Battery Cautions

- **Caution (English)**

There is a danger of explosion if the battery is incorrectly replaced. Replace only with the same or equivalent type recommended by the manufacturer. Dispose of used batteries according to the manufacturer's instructions.

- **Warnung (German)**

Explosionsgefahr durch falsches Einsetzen oder Behandeln der Batterie. Nur durch gleichen Typ oder vom Hersteller empfohlenen Ersatztyp ersetzen. Entsorgung der gebrauchten Batterien gemäß den Anweisungen des Herstellers.

- **Attention (French)**

Il y a danger d'explosion si le remplacement de la batterie est incorrect. Remplacez uniquement avec une batterie du même type ou d'un type équivalent recommandé par le fabricant. Mettez au rebut les batteries usagées conformément aux instructions du fabricant.

- **Cuidado (Spanish)**

Peligro de explosión si la pila es instalada incorrectamente. Reemplace solamente con una similar o de tipo equivalente a la que el fabricante recomienda. Deshágase de las pilas usadas de acuerdo con las instrucciones del fabricante.

- **Waarschuwing (Dutch)**

Explosiegevaar indien de batterij niet goed wordt vervagen. Vervanging alleen door een zelfde of equivalent type als aanbevolen door de fabrikant. Gebruikte batterijen afvoeren als door de fabrikant wordt aangegeven.

- **Varning (Swedish)**

Explosionsfara vid felaktigt batteribyte. Använd samma batterityp eller en likvärdigt typ som rekommenderas av fabrikanten. Kassera använt batteri enligt fabrikantens instruktion.

Blank

Symbols

#define	40
#INT_VEC	45, 121
#JUMP_VEC	122, 123
+5 V power supply	127
holdup time	129
/AT	97
/CTS	60, 64
/CTS0	44
/DCD0	60
/DREQ0	33, 34
/DREQ1	33, 34
/INT0	34
/INT1	34
/INT2	33, 34
/PFO	126, 130
/RAMCE	126
/RAMCEIN	126
/RDX	97
/RESET	33, 34, 126, 127
/RTS0	62
/STBX	97
/USER1–/USER3	33
/WDO	126
/WRX	97
=(assignment)	
use	70
4-bit bus operations ...	97, 98, 100
5 × 3 addressing mode	99
8-bit bus operations ...	97, 99, 101
9th-bit address mode	51
9th-bit binary communication ..	54, 55
9th-bit transmission	51

A

A0X	97
A1X, A2X, A3X	97, 98

addresses

encoding	99
modes	99
PLCBus	99
ADM691 (power supervisor IC)	126
applications	
relays	31
solenoids	31
stepping motors	31
ASCII	60, 62, 63
Control Register A	62
Control Register B	63
status registers	60
ASCII characters	
and modem commands	44
asynchronous	
channels	62
serial ports	58
asynchronous serial communication	
interface. <i>See</i> ASCII	
attention line	97

B

background routine	100
backup battery	127
battery	
cautions	132
replacing	132
battery-backed clock	38
battery-backed RAM	
.....	13, 26, 44, 123
baud rate	24,
..	32, 46, 54, 57, 58, 64, 65
serial ports	57
bidirectional data lines	97
BL1600	12
default communication rate ...	21
features	13
power supply	18
setup	18

block diagram	
BL1600	30
brownouts	122, 123, 126, 128
buffer	
receive	43, 44, 46, 47, 54, 55
initialization	46
reading	46
transmit	43, 47, 55
initialization	46
writing	47
bus	
control registers	101
digital inputs	101
expansion	96,
.....	97, 98, 99, 100, 101
8-bit drivers	104
addresses	100
devices	100, 101
functions	102, 103, 104, 105
rules for devices	100
software drivers	101
LCD	97
operations	
4-bit	97, 98, 100
8-bit	97, 101
PLCBus	43, 45
BUSADR0	98, 99
BUSADR1	98, 99
BUSADR2	98, 99
BUSADR3	104, 105
BUSRD0	101, 102, 103, 105
BUSRD1	101, 102
BUSWR	102
C	
CARRIAGE RETURN	
as modem command terminator ..	44
CE compliance	16
check sum	51, 54, 55
computing	50
check_opto_command	54
checking for modem commands ..	49
CKA1	62
CKA1 disable	62
CKA1/TEND0	62
CKA1D	62
Clear to Send/Prescaler	64
clock	
battery-backed	38
external	58
frequency	
system	13,
.....	32, 57, 58, 63, 64, 65
millisecond	39
real-time	13, 38, 39
time/date	13, 38, 122, 127
CMOS	30
CNTLA	61
CNTLB	63
CNTLB0	57
CNTLB1	57
COMMAND mode	
modem communication	44
command protocol	
master-slave	51
common problems	
programming errors	70
wrong COM port	68
communication	
Dynamic C	123
function libraries	56
initialization routines	45
RS-232 ..	13, 32, 43, 44, 46, 47
RS-485	13, 30,
.....	32, 51, 52, 54, 55, 56
serial	13, 30, 32, 43,
..	44, 45, 46, 52, 54, 55, 57,
.	58, 59, 60, 62, 63, 65, 116
interrupts	43
master-slave	51, 54, 55
compile-time interrupt directive ..	50
connections	
RS-485 two-wire network	52
connectors	
26-pin PLCBus	
pin assignments	96
screw	77
costatements	39

counter input	37	Dinit_z0	43, 45, 48
counters		Dinit_z1	43, 45
virtual timer	42	diodes	
CPLC_LIB	41	protective	31
CRC	51, 54, 55	DIP relays	96
computing	50	direct drivers	36
CSI/O	50, 61	disabling interrupts	50
CTS	43, 44, 46, 59, 61	DMA channels	50
CTS enable	61	Z180 serial channels 0 and 1 .	50
CTS/PS	64	disabling the RS-485 driver	56
CTS1	61	display	
cyclic redundancy check. <i>See</i> CRC		liquid crystal	97
D		divide ratio	64
D0X-D7X	97	Dkill_z0	47
Data Carrier Detect	60	DMA	
Data Format Mode Bits	62	channels	37
DATA mode		disabling interrupts	50
modem communication	44	counter	37
date and time	38	interrupts	37
DCD0	58, 59, 61	request	33, 34
DCD0 line to ground	59	DMA0Count	37
Ddelay_100ms	49	DMA1Count	37
deciphering modem commands ...	49	DMAFLAG0	37
default jumper settings	74	DMASnapShot	37
delay		downloading data	43, 44, 48
in slave response	55	downloading programs	45, 50
modem communication ...	49, 50	DR	64
delay_1sec	49	Dread_z0	47
DelayMs	39	Dread_z01ch	46
DelaySec	39	Dreset_z0rbuf	47
Developer's Kit	15	Dreset_z0tbuf	47
development tools	15	Drestart_z0modem	49
Dget_modem_command	49	drivers	
DIGIN1...DIGIN12	41	high-current	31
digital inputs ... 13, 30, 36, 39, 41		sinking	15
pinout	31	software	36
digital outputs . 13, 30, 36, 39, 41		direct	36
high-voltage driver specifications		expansion bus	101
78		expansion bus 8-bit	104
pinout	31	high-level	36
dimensions		indirect	36, 41
BL1600	73	low-level	36
Dinit_uart	43, 45	relay	101
		virtual	36, 39, 40, 41, 42

drivers	
software	
virtual	
function library	40, 41
variables	40
sourcing	15
installation	92
DRIVERS.LIB	35, 101
DTR	44
Dwrite_z0	47
Dwrite_z01ch	47
Dxmodem_z0down	48
Dxmodem_z0up	48
Dynamic C	15, 21
communications	123
libraries	35
programming BL1600	24
programming port	50
serial options	21
standard version	35
will not start	69
Dz0_circ_int	49
Dz0modem_chk	49
Dz0send_prompt	47
E	
E	33, 34
echo option	43, 44, 46
ee_rd	109
ee_wr	109
EEPROM	13, 30, 50, 57
baud rate	108
changing stored parameters ...	109
clock speed	109
constants	121
initialization	108
library routines	109
operating mode	108
programming	108
run	108
writes	
lifetime	109
EFR	61
EFR bit	61
eioPlcAdr12	102
eioReadD0	103
eioReadD1	103
eioReadD2	103
eioResetPlcBus	102
eioWriteWR	104
electrical specifications	72
EN485	30, 31, 36
environmental specifications	72
EPROM	13,
.....	24, 25, 26, 38, 39, 45
copyright	27
flash	26, 38
how to write data	38
programming	25
Epson 72421 real-time clock	13
execution times	115
Exp-A/D12	96
expansion boards	13
reset	102
expansion bus	13,
....	96, 97, 98, 99, 100, 101
8-bit drivers	104
addresses	100
devices	100, 101
digital inputs	101
functions ...	102, 103, 104, 105
rules for devices	100
software drivers	101
expansion register	100
external clock	58
EZIOBL17.LIB	101
EZIOGPL.LIB	101
EZIOMGPL.LIB	101
EZIOPL2.LIB	101
EZIOPLC.LIB	101
EZIOTGPL.LIB	101
F	
FE	61, 62
flash EPROM	26, 38
how to write data	38
float	
use	70

- framing error 61
 - frequency
 - system clock 13,
 - 32, 57, 58, 63, 64, 65
 - function libraries 36, 98
 - serial communication 56
 - virtual driver 40, 41
- ## G
- `getcrc` 50
- ## H
- H1
 - digital inputs 31
 - H2
 - digital outputs 31, 36
 - H3
 - RS-232 serial port 32
 - H4
 - miscellaneous outputs 33, 34
 - H5
 - PLCBus 96
 - handshaking
 - RS-232 43
 - hardware reset 40
 - Hayes Smart Modem 44, 49
 - HC1...HC6 36, 41
 - HC1...HC7 31
 - headers
 - H1 84, 87
 - H2 84, 87
 - H3 84
 - H4 84, 87
 - H5 84, 87, 96
 - J2 32
 - Prototyping Board ... 85, 87, 88
 - heat dissipation 77
 - high-current drivers 31
 - high-current outputs
 - 30, 31, 36, 41
 - pinout 31
 - high-level software drivers 36
 - high-speed DMA counter 37
 - high-voltage drivers
 - K 93
 - specifications 78
 - `hitwd` 128
 - holdup time
 - power-failure management
 - 127, 129
 - how to write data to flash EPROM
 - 38
- ## I
- I/O interface 36
 - ICL7662 85
 - IEF1 129
 - IEF2 129
 - IN00–IN11 30
 - indirect drivers 36, 41
 - inductive spikes 31
 - initialization
 - serial communication 45
 - transmit buffer 46
 - Z180 Port 1 51, 54
 - initialization
 - receive buffer 46
 - initiating
 - serial communication 47, 55
 - `inport` 57, 102,
 - 103, 105, 112, 116, 122
 - input
 - counter 37
 - digital 13,
 - 30, 36, 39, 41, 82, 87
 - RS-232 46, 47
 - input/output interface 36
 - inputs/outputs
 - cycle timing 114
 - devices 116
 - map 116
 - space 116
 - `int`
 - type specifier, use 70
 - INT1 50
 - INT2 50

interface	
I/O	36
intermediate variables	36
interrupt handling	
Z180 Port 0	45
interrupt-driven driver	59
interrupt-driven transmission	55
interrupts	60, 61,
.....	97, 100, 121, 123, 129
disabling	50
DMA	37
interrupt service routines	36,
.....	49, 50, 56, 122, 123
interrupt vectors ...	57, 121, 123
default	121
vector table	45, 50
nonmaskable	
.....	122, 123, 127, 128, 129
power failure	122,
.....	123, 127, 128, 129
priorities	124
routines	100
serial	45, 123
and debugging	45
serial communication	43
virtual driver	39
invoking the virtual driver ..	39, 40
J	
J1	
EEPROM write-protect	75
enable watchdog timer	75
EPROM size	26, 75
flash/non-flash EPROM configura-	
tion	75
program/run mode	25
program/run mode configuration	
.....	19, 75
serial communication	75
serial communication configura-	
tion	32
SRAM size	75
J2	18
high-current outputs	31
RS-485	31
jump vectors	123
jumper settings	
default settings	74, 75
EPROM size	26, 75
J1	19, 25, 26, 32, 75
program/run mode	75
programming mode	19
programming options	19
run mode	19, 25
serial communication	32, 75
SRAM size	26, 75
K	
K	31, 93
KILL	35
L	
lc_wdogarray	40
LCD	97
LCD bus	97
LCDX	97
leap year	38
libraries	
EPROM vs. source	35
function	36, 98
communication	56
virtual driver	40, 41
replacing EPROM functions ..	35
source	35
liquid crystal display	97
literal (C term)	
use	70
lithium backup battery	122
lithium battery	132
LM340	84
low-level software drivers	36

M

master message format 51, 54
master-slave
 command protocol 51
 library functions 51
 networking 51, 56
 serial communication 51, 54, 55
 software 54
mechanical dimensions 73
mechanical specifications 72
memory 13
 access times 114
 battery-backed . 26, 44, 45, 123
 extended
 and uploaded data 48
 random access 39
 read-only 13, 38, 39
memory cycles 113
 execution timing 115
 inserting wait states 114
 LIR cycles 113
 standard 114
memory map 112
millisecond clock 39
miscellaneous outputs
 pinout 33
misticware 55
mktime 38
mktm 38
MOD0 62
MOD1 61, 62
MOD2 62
mode
 691 127
 standby 127
 8-bit data 51
 9th-bit address 51
 addressing 99
 communication
 ASCII 47
 binary 47
 mode parameter 46
 data format 62

mode

modem
 command 44, 48
 data 44, 48
 mode parameter 46
 RS-232 44
multiprocessor 62, 63, 64
multiprocessor communication 63
operating
 program 19
 run 19, 25
RS-232
 mode parameter 46
standby 127
supervisor 127
modem 48
 commands 44, 49
 deciphering 49
 termination 44
 communication 46
 checking for commands 49
 delay 49, 50
 restarting 49
 control lines 58
 options 43, 44
MP 63, 64
MPBR/EFR 62
MPBT 64
MPE 63
Multiprocessor Bit Receive/Error
 Flag Reset 62
Multiprocessor Bit Transmit 64
Multiprocessor Enable 63
Multiprocessor Mode 62, 64
N
N_WATCHDOG 40
network connections
 RS-485 52
NMI_VEC 122, 123
NO_CARRIER message 44
nonmaskable interrupts
 122, 123, 127, 128, 129
nonvolatile memory 39

NOTIMERS 40
 NULL modem 44, 49
 number of bits 46

O

op_init_z1 54
op_kill_z1 56
op_rec_z1 55
op_send_z1 55
 operating modes
 flowchart 24
 run mode 25
 operating temperature 13
 opto 22 binary protocol
 51, 54, 55, 56
optodelay 55
 OUT1...OUT6 30, 31, 36
 OUTB1...OUTB8 30, 36, 41
 outport 57,
 102, 103, 105, 112, 116
 outputs
 digital 13,
 30, 36, 39, 41, 82, 87
 high-current 30, 31, 36, 41
 RS-232 43, 47
 sourcing 90
 overload
 power failure 128
 overloaded power supply 122
 overrun 61
 overrun error 61
OVRN 61, 62

P

parity 46, 64
 even/odd 64
 parity error 61
PE 61, 62
PEO 64
phy_addr 48
 pin 1 locations 76
 pinouts
 digital inputs 31

pinouts
 digital outputs 31
 header H1 31
 header H2 31
 header H3 32
 header H4 33
 header J2 31
 high-current outputs 31
 miscellaneous outputs 33
 RS-485 31
 serial port 32
 PLCBus 13, 34, 43,
 45, 96, 97, 98, 100, 101
 26-pin connector
 pin assignments 96
 4-bit operations 97, 99
 8-bit operations 97, 99
 addresses 99
 memory-mapped I/O register 98
 reading data 98
 relays
 DIP 96
 drivers 101
 writing data 98
 ports
 serial 43, 57, 59
 asynchronous 58
 baud rate 57
 interrupt-driven 57
 polling 57
 power dissipation 13
 power failure
 holdup time 129
 interrupt handler 130
 interrupts 13,
 122, 123, 127, 128, 129
 sequence of events 127
 power for external accessories 77
 power supply 18
 connection 18
 specification 18
 power-on reset 126
 prescaler 64
 programmable ROM 13, 38, 39

programmable timer	13	receiver interrupts	59, 60, 61
programming	39	receiver shift register	61
protective diodes	31	registers	
protocol		other	119
command		Z180	116
master-slave	51	regulated input voltage ...	122, 127
Prototyping Board		reload_vec	45, 50
.....	13, 14, 82, 83, 84	replyOpto22	55
header signals	87, 88	Request to Send	62
power rails	82, 85	reset	
voltage converter	84	expansion boards	102
PRT	50	hardware	24
pull-up resistor	30	system	122, 123, 127
R		reset threshold	126
R1	126, 127	resetZ180int	50
R2	126, 127	restarting modem communication ..	
RAM	45	49
battery-backed	13, 26, 44, 123	ROM	13
static	26, 39	programmable	
rbuf_there	55	13, 38, 39, 45, 50, 57
RDR	61	RS-232	
RDRF	59, 61, 63	handshaking	43
RE	63	programming BL1600	19
read data register full	61	serial communication	13,
read-only memory	19, 32, 43, 44, 46, 47
.....	13, 38, 39, 45, 50, 57	serial input	46, 47
read12data	103	serial output	43, 47
read24data	105	software support	46
read4data	104	RS-232 serial port	
read8data	105	pinout	32
reading data on the PLCBus		RS-485	
.....	98, 103	disabling driver	56
real-time clock	13, 38, 39	network connections	52
real-time kernel	39, 40, 49, 55	pinout	32
receive buffer		serial communication	13, 19,
.....	43, 44, 46, 47, 54, 55	30, 32, 51, 52, 54, 55, 56
initialization	46	RSR	61
reading	46	RTS	43, 44, 46
receiver data register	61	RTS0	62
Receiver Data Register Full	61	RTS1	58
receiver enable	63	RUNKERNEL	40, 49
Receiver Interrupt Enable	61	RX line	44
		RXS	61

S

sample programs	36, 56
virtual driver	40
SCL	30, 36
screw connectors	77
screw terminals	32, 77
SE1100	96
select PLCBus address	102
sendOp22	54
SER0_VEC	45
Serial Channel 0	
block diagram	58
Serial Channel 1	58
serial communication	13,
. 19, 30, 32, 43–46, 52, 54,	
. 55, 57–60, 62, 63, 65, 116	
master-slave	51, 54, 55
serial interrupts	45, 123
and debugging	45
serial ports	43, 57, 59
asynchronous	58
baud rate	57
interrupt-driven	57
low-level utility functions	57
polling	57
serial transmission	
initiating	47
terminating	47
SERIAL.LIB	35
set12adr	102
set16adr	102
set24adr	104
set4adr	103
set8adr	105
shadow registers	100
shutdown	122, 128
sinking drivers	15
specifications	78
slave identification number	51
slave response delay	55
slave response format	51, 55
Smart Modem	
Hayes	49
software	15
libraries	36, 40, 41, 56, 98
timers	40, 42
source (C term)	
use	70
Source/Speed Select	63
sourcing drivers	15, 90
specifications	78
specifications	71
electrical	72
environmental	72
mechanical	72
SS0	63
SS1	63
SS2	63
startup sequence	24
STAT0	60
static RAM	26, 39
stop bits	46
struct tm	38
support libraries	56
suspend	49, 55
sysclock	57
system clock frequency	13
system ... 32, 57, 58, 63, 64, 65	
system reset	122, 123, 127
T	
T1I	42
T1I...T10I	41
T1O	42
T1O...T10O	41
T1RLD	42
T1RLD...T10RLD	41
TDR	62
TDRE	59, 60, 62
TE	62
temperature	
operating	13
TEND0	62
TIE	60
time and date	38, 122, 127
time/date clock ... 13, 38, 122, 127	
registers	118

timer 116
 programmable 13
 watchdog 13, 24, 40, 123
 virtual 39, 40

timers
 PRT 50
 virtual 39, 40, 41, 42

tm 38

tm_rd 38

tm_wr 38

transmission
 initiating 47, 55
 interrupt-driven 55

transmit buffer 43, 47, 55
 initialization 46
 writing 47

Transmitter Data Register 60
 empty 60

transmitter enable 62

transmitter interrupt 59

Transmitter Interrupt Enable 60

troubleshooting
 baud rate 69
 cables 68
 com port 69
 communication mode 69
 repeated interrupts 69
 watchdog timer 69

TX line 44

U

U2 126, 130

U9 (ADM691) 126

UDN2895 79

UDN2985 78, 90, 91

ULN2003 78, 90

unregulated input voltage .. 122, 127

up_digin 36

up_setout 36

uplc_init 40

uploading data 43, 44, 48

V

VBAT 126

VIODrvr 40

VIOInit 40

virtual drivers... 36, 39, 40, 41, 42
 function library 40, 41
 Invoking 39, 40
 sample programs 40
 services 39
 variables 40

virtual timers 39, 40, 41, 42

virtual watchdog timers 39, 40

voltage divider
 power failure 126, 127

VWDOG.C 40

W

watchdog timer 13,
 24, 40, 69, 123, 126
 virtual 39, 40

WDI 126

write12data 104

write24data 105

write4data 104

write8data 105

WriteFlash 38, 39

writing data on the PLCBus
 98, 104

X

xdata 38, 48

XMODEM
 commands 48
 protocol 43, 44, 48

XP8100 96

XP8200 96

XP8300 96

XP8400 96

XP8500 96

XP8600 96

XP8700	43, 45, 96, 97, 101	z1_op_int	56
connection	20	Z180	37
programming BL1600	20	internal I/O registers	116
XP8800	96, 101	Z180	
XP8900	96	Port 0 ...	43, 45, 46, 47, 49, 50
Z		interrupt handling	45
z0binaryreset	47	Port 1	43, 51, 52, 56, 121
z0binaryset	47	initialization	51, 54
z0modemset	48	serial channels 0 and 1	
z0modemstat	48	disabling interrupts	50
		z180baud	57

SCHEMATICS



Z-World, Inc.
2900 Spafford Street
Davis, California 95616-6800 USA

Telephone: (530) 757-3737
Facsimile: (530) 753-5141
Web Site: <http://www.zworld.com>
E-Mail: zworld@zworld.com

Part No. 019-0016
Revision E

